

June 18, 2020

Peter Brixius- City Manager; Craig City Council  
City of Craig  
300 W. 4<sup>th</sup> Street  
Craig, CO 81625

**RE:   *Award Recommendation***  
***City of Craig, CO; Sludge Handling Improvements (Phase 1)***

Dear Peter and City Council,

The City received four bids, on July 11, 2020, for Phase 1 of the sludge handling improvements project. SGM and the City performed through evaluations of the two lowest cost bids, from RCD and Duran & Pearce. Review of contractor provided information and interviews with both bidders were conducted. To aid in award recommendation, a bid comparison matrix was generated and is attached hereto as Exhibit A.

For reference, the bid tabulation with total prices ranging from \$566K to \$1.27M is attached hereto as Exhibit B.

The two lowest bids were reviewed for completeness. Both bidders submitted all required information. Additional qualifications, including relevant projects, proposed schedules, subcontractor list, and references were requested from the two lowest bidders. The submitted qualification packets are attached as Exhibit C.

City staff worked with SGM to review the qualification submittals. Both bidders submitted information demonstrating compliance with the minimum project experience requirements.

The project references provided by the low bidder, RCD construction, were contacted. The low bidder provided two project references. SGM was able to contact one of the two, who offered positive endorsements for the low bidder. Additionally, SGM contacted the Town Manager of a community where RCD performed a large project, and again received a positive referral for the bidder. The City Staff has worked extensively with the second lowest bidder, Duran and Pearce, and provided positive referrals for them.

SGM has also reviewed the two lowest bidders proposed subcontractor lists. SGM takes no exception to the firms listed on either submittal.

SGM and City Staff, directly interviewed the lowest two bidders via conference calls. From these conversations and provided qualifications SGM and City Staff developed a bid comparison matrix for City Council to assess the bids. The comparison matrix attached as Exhibit A,

includes not only pricing, but documents other project considerations that should weigh into contractor selection.

SGM finds that either contractor is qualified. Review of information and interview with Duran clearly demonstrates a high understanding of the project with ample similar experience. Review of information and interview with RCD indicates a good understanding of the project, a degree of relevant experience and that by all accounts they can probably do the job. The City's choice is between lower cost bid from a contractor based in Hayden, CO and a qualified in-town contractor. Both have merits. SGM will support award to either contractor and will work closely with the successful bidder to help foster a successful project. SGM respects the power of City Council to review the attached documents and make a final decision about bid award.

If you have any questions or we can be of any further service, please contact me directly.

Respectfully,

**Schmueser Gordon Meyer Inc.**

A handwritten signature in blue ink, appearing to read 'Alex Kordick', is written over a horizontal line.

Alex Kordick, P.E.  
Design Engineer

Encl: Exhibit A – Bid Comparison Matrix  
Exhibit B – Bid Tabulation  
Exhibit C – Contractor Qualification Packets  
Exhibit D – RCD bid package (complete)  
Exhibit E – Duran and Pearce bid package (complete)

Exhibit A: Bid Comparison Matrix

**Craig Sludge Improvements Phase 1- Bid Comparison Matrix**

<b>Contractor</b>		<b>Duran and Pearce</b>	<b>RCD Construction</b>
<b>Bid</b>	<b>Bid Price</b>	\$699,022.50	\$565,698.60
	<b>Bid inconsistencies</b>	none observed	expecting ~2x's as much sludge as other contractors
<b>Site Familiarity</b>	<b>Pre-Bid Attendance- walked the site</b>	Owner and Electric Subcontractor attended pre-bid mtg.	Project manager did not attend pre-bid, project foreman attended
	<b>Project Familiarity</b>	Submitted several questions about the plans prior to bidding	Asked no questions prior to bidding
	<b>Local Affiliation</b>	Local to the City of Craig	Main office in Hayden, but majority of work and Staff out of Loveland.
<b>Project Planning</b>	<b>Sub Contractors</b>	Provided a list of reputable sub-contractors	Provided a partial list of reputable sub-contractors; electrical sub has not been secured.
	<b>Work Crew(s)</b>	6-men on site at a time (provided by Duran); the same local crew throughout project duration	6-men on site at a time (provided by RCD); may or may not be the same crew; may or may not be local
	<b>Schedule</b>	Provided a schedule to meet all deadlines. Construction to begin Mid-July.	Provided a schedule to meet all deadlines. Construction to begin August 10th.
	<b>Dewatering</b>	Anticipates dewatering from Mack Ponds through ox-bow. Stressed use of trench boxes for crew safety.	Anticipates, laying line quickly to mitigate dewatering. Expects little dewatering necessary, but has pumps available if more dewatering is necessary.
	<b>Equipment Allocation</b>	Allocated 2 excavators + ancillary equipment for project	Allocated 3 trackhoes+ ancillary equipment for project
<b>References</b>	<b>Relevant Projects</b>	Provided a list of relevant projects to demonstrate experience including boring (both RR and River) and HDPE installation,	Provided a list of relevant projects to demonstrate experience. (no boring experience, but sub contracted to firm with experience)
	<b>Number of Unique References Provided</b>	6	2
	<b>References Contacted</b>	City Staff provided very positive references through personal experience on past projects.	Contacted Mike Havens at Colorado State Parks, provided a very positive reference for RCD. Contacted Matt Medisco with the Town of Hayden who gave a positive reference.



## Exhibit B: Bid Tabulation



CITY OF CRAIG 2020 SLUDGE HANDLING IMPROVEMENTS - PHASE I

Project No. 2013-520.015 - Bid Date June 11, 2020

				Duran and Pearce		RCD Construction		Anson Excavation		Schmueser and Associates		Max Unit Cost	Min Unit Cost	Average Unit Cost
Item #	Estimated Quantity	Unit	Description	Unit Price	Total Price	Unit Price	Total Price	Unit Price	Total Price	Unit Price	Total Price			
1	2	EA	Installation of New Sludge Pumps	60,500.00	121,000.00	48,800.00	97,600.00	87,500.00	175,000.00	89,050.00	178,100.00	\$89,050.00	\$48,800.00	\$71,462.50
2	2730	LF	Installation of 6" DR9 (250 psi) DIPS HDPE Sludge Line	65.75	179,497.50	38.80	105,924.00	87.30	238,329.00	197.00	537,810.00	\$197.00	\$38.80	\$97.21
3	2	EA	Existing System Tie-Ins	4,000.00	8,000.00	13,000.00	26,000.00	9,300.00	18,600.00	21,850.00	43,700.00	\$21,850.00	\$4,000.00	\$12,037.50
4	1	EA	Bore Under Yampa River	57,750.00	57,750.00	45,905.00	45,905.00	93,500.00	93,500.00	43,200.00	43,200.00	\$93,500.00	\$43,200.00	\$60,088.75
5	1	EA	Bore Under UPRR ROW	82,500.00	82,500.00	67,000.00	67,000.00	172,000.00	172,000.00	142,550.00	142,550.00	\$172,000.00	\$67,000.00	\$116,012.50
6		GAL	Provide Sludge Removal	0.07	45,240.00	0.05	74,970.00	0.06	41,918.88	0.07	54,880.00	\$0.07	\$0.05	\$0.06
			gallons of sludge	696,000		1,470,000		698,648		784,000		1,470,000	696,000	912,162
7	1	LS	Mobilization/Demobilization	42,035.00	42,035.00	38,000.00	38,000.00	24,000.00	24,000.00	45,900.00	45,900.00	\$45,900.00	\$24,000.00	\$37,483.75
				<b>TOTAL</b>	<b>\$536,022.50</b>	<b>TOTAL</b>	<b>\$455,399.00</b>	<b>TOTAL</b>	<b>\$763,347.88</b>	<b>TOTAL</b>	<b>\$1,046,140.00</b>			

Alternates

8	ALT A	EA	Primary Extension	95,000.00	<b>\$95,000.00</b>	52,099.60	<b>\$52,099.60</b>	113,500.00	<b>\$113,500.00</b>	111,430.00	<b>\$111,430.00</b>
9	ALT B	EA	Secondary Extension	68,000.00	<b>\$68,000.00</b>	58,200.00	<b>\$58,200.00</b>	111,800.00	<b>\$111,800.00</b>	116,990.00	<b>\$116,990.00</b>
<b>Total + Alternates</b>				<b>\$699,022.50</b>		<b>\$565,698.60</b>		<b>\$988,647.88</b>		<b>\$1,274,560.00</b>	

## Exhibit C: Contractor Qualification Packets

## Exhibit C1 – RCD Packet



*Water Main Installation and Repair  
Sewer Main Installation and Repair  
Mass Excavation/Site Development*

*Flood Mitigation*

*River Restoration*

*Erosion Control*

*Storm Drainage*

*Clearing / Grubbing*

*Excavation*

*Site Grading*

*Underground Dry Utilities*

*Overburden Removal*

*Road Construction*

*Land Reclamation*

*Landfill reclamation and cell construction*

*Snow Plowing*

*Concrete*

*Asphalt Parking/Drives*

*150 N. 2nd St.  
Hayden, CO 81639  
(970)276-2192  
(970)756-1150*

## *REQUEST FOR QUALIFICATIONS (RFQ)*

*RCD Construction is a rapidly growing company that began on February 8<sup>th</sup>, 2014. We are committed and faithful to our customers and work very hard to ensure that our customers' needs are met. We are well known for completing jobs in a timely and accurate manner by implementing unique and skillful strategies to get the job done. We are eager to take part in the upcoming project and feel as though we would be an excellent fit.*

*We have a team that helps implement the best routes and find ways that work best for both our company and yours. We hope to be considered for this upcoming project.*

*RCD Construction has performed work throughout the entire state of Colorado and currently have the following project(s) in process.*

- *Mission Village/Mission Homestead*

*35 house subdivision with attached 7 building apartment complex and .5 miles of new city roads*

*Evans Colorado*

*Combined value of \$2.6 million*

*Work includes*

- *Over lot grading*
- *Road and building sub ex*
- *Water main*
- *Sewer main*
- *Site concrete*

*76% complete as of 03.20.2020*

- *Prairie Center Village Phase 2*

*95 House subdivision in Brighton Colorado*



## ***REQUEST FOR QUALIFICATIONS (RFQ)***

***10% complete***

***Valued at \$1.6 million***

***On the books for 2020***

- ***Saratoga Landfill reclamation- Upper Saratoga Waste***
- ***Bear creek Bridge replacement – Routt county Road and Bridge***

***Some of our Projects completed in the last 3 years include the following:***

### ***-Atlantic Aviation FBO***

*Value: \$2.2 Million*

*New 30 Ac site development for a 30 AC aircraft apron*

*New building*

*New parking lot*

*Water main*

*Sewer main*

*GC: Tectonic Management*

*Owner: Atlantic Aviation*

### ***-Crawford State park Trail project***

*New 6,000 face SF redi-Rock retaining wall*

*Value-\$655,000*

*Owner: Colorado parks and Wildlife*

## ***REQUEST FOR QUALIFICATIONS (RFQ)***

### ***~Steamboat Lake & Stagecoach Lake Lagoon Liner Rehabilitation Project***

*Value: 1.05 Million*

*5 wastewater lagoon liner replacement and rehabilitation*

*Owner: Colorado Parks and Wildlife*

### ***~Steamboat Lake Water Line rehabilitation***

*Value: \$229,000.00*

*Replace old/outdated waterlines for campgrounds*

*Owner: Colorado Parks and Wildlife*

### ***~Stop-N-Go storage Complex (Steamboat Springs)***

*Value: \$311,000.00*

*Site development for 7 ac storage complex*

*Owner: Zunie Construction & Development*

### ***~Town of Hayden Watermain & roadway reconstruction***

*Value: \$701,000.00*

*New Water main and Roadway reconstruction*

*Owner: Town of Hayden (Hayden, Colorado)*

### ***~GHH Ranch (Dunkley Pass)***

*Value: \$388,000.00*

*Private House*

*Owner: Gates Family*

*GC: HLCC. Steamboat Springs*



## *REQUEST FOR QUALIFICATIONS (RFQ)*

*~Staybridge Suites (Littleton CO)*

*Value: \$672,000.000*

*New Hotel*

*Owner: Choice Hotel Groups*

*GC: Northridge Construction*

*A lot of our success stories that have bettered our company in many ways include utility work and site development along with taking on complex jobs nobody else would.*

*Our bonding capacity has been instrumental to the growth of our company. Although we have only been in business for six years, we have a bonding capacity of \$5 million single job and \$6.5 million aggregate. Showing a capacity of this amount for a young company such as ourselves regarding the countless audits and financial briefings with our insurance and bonding agencies prove one thing. We do things right.*

*RCD Construction employee numbers have done nothing but grow with us since the start of the company. The larger the demand for our work, the more employees we have hired. We Currently have a staff of 29 qualified individuals full time, with upwards of 50 in the summer months. RCD Construction has never been terminated, late, or in default from any project before, nor have we ever received any permit violations.*

### *References*

*Atlantic Aviation FBO*

## *REQUEST FOR QUALIFICATIONS (RFQ)*

*At the Atlantic Aviation FBO project RCD crews developed 30 acers of vacant land at the Yampa Valley Regional Airport.*

- This work included but not limited to,*
- 50,000 CY cut/fill*
- 2,000 Lf water main*
- 60,000 tons of aggregate production and import from RCD's gravel pit in Hayden, CO*
- Sewer main construction*
- Site grading and asphalt prep*

*Reference:*

*Andrew Barone, Techtronic management, Project manager*

*303.403.1228*

*[abarone@tectonicdesignbuild.com](mailto:abarone@tectonicdesignbuild.com)*

### *Steamboat Lake Lagoons*

*At Steamboat Lake and Stagecoach lake we were able to take on a great project. At each lake there are ponds for wastewater where we were assigned to clean and replace the liner at the bottom of each pond (a total of 5 ponds were completed). This took quite a bit of multitasking and it was imperative that we kept on schedule due to having so many jobs to do. We had to coordinate with surveyors, dredgers, liner crew and many other groups of people to ensure that each pond was completed on time and in a safe manner. Our method was to start with one and follow a very detailed schedule so that once we moved on to the next pond others were able to do their part on the first pond. We continued this process till the end and were successful at coordination between all sub-contractors and parks staff.*

## *REQUEST FOR QUALIFICATIONS (RFQ)*

*Some of the duties completed for the Steamboat Lake / Stagecoach Lake Lagoon Liner Project are as follows:*

- *Drain each lake and export water and sludge*
- *Set up preventative water blockage systems*
- *Remove old liner, clean up weeds/trash/dirt - Export*
- *Remove concrete slabs, trench each pond, and export*
- *Grade/compact the bottom of the ponds*
- *Import rock and Backfill*
- *Pour concrete slabs*
- *Installed bypass pipes from one pond to another*

*Reference: Mike Havens (Colorado Department of Parks and Wildlife)  
Havens - DNR, Mike [mike.havens@state.co.us](mailto:mike.havens@state.co.us)  
970-434-6858*

### *Steamboat lake water line*

*We also had the chance to perform another project at Steamboat Lake at the same time. On this project we installed a waterline to Steamboat Lake campgrounds. This was also an extensive project that required dedicated attention to detail and ensuring that the job was completed accurately.*

*These are some of the duties we were able to fulfill with this job:*

- *Organization of parts*
- *Testing to ensure quality*
- *Importing and export gravel, dirt, and equipment*
- *Dugout, laid pipe, backfilled, and compacted*
- *Connected Hydrants and Curb Stop Valves*
- *Pipe pulling and bursting*

*Reference: Mike Havens (Colorado Department of Parks and Wildlife)  
Havens - DNR, Mike [mike.havens@state.co.us](mailto:mike.havens@state.co.us)*

## *REQUEST FOR QUALIFICATIONS (RFQ)*

970-434-6858

*Another job that seemed like a great one to share is our Cherry creek job. On this job we restored the Dam Face Trail that was damaged after the 2015 Flood. This required a lot of natural land work and we had to make sure that we were environmentally friendly while completing this assignment.*

*Some things we performed on this job:*

- *Subgrade rework*
- *Rework of 24"-60" boulders*
- *Hauling/Exporting materials*
- *Importing crusher fines to restore trail*

*Shawn Krier Colorado State Parks  
303-883-8249*

*Thank you for your consideration,*

*RCD Construction, Inc.*

*Ryan Domson*

*REQUEST FOR QUALIFICATIONS (RFQ)*

*List of subs and suppliers*

- *Kinetic Industries*  
*Pipe boring*  
*Sludge hauling*
- *Camblin Inc.*  
*Pipe welding*
- *Core and Main*  
*Polly pipe and fittings*
- *Netzsch*  
*Sludge pumps*

RCD Construction, Inc  
Ryan Domson

Mon, 8/10/2020

1

[illegible]

## Craig WWTP sludge line replacement

RCD Construction, Inc  
Ryan Domson

Project Start:

Mon, 8/10/2020

Display Week:

6

[illegible]

## Exhibit C2 – Duran and Pearce Packet





## *"HELD TO A HIGHER STANDARD"*

June 14th, 2020

SGM

Alex Kordick / Chad Paulson

Trevor Campbell & Shane Baker

City of Craig

300 W. 4<sup>th</sup> St

Craig, Co 81625

### **RE: 2020 SLUDGE HANDLING IMPROVEMENTS – Follow Up**

Alex,

Thank you for giving Duran & Pearce Contractors, Inc the opportunity to address SGM's follow up questions in regard to the 2020 Sludge Handling Improvements for the City of Craig. Duran & Pearce Contractors submitted a proposal on Thursday, June 11<sup>th</sup>, 2020 and are aware that we were not low bid. However, we are confident in our proposal and believe we are the most qualified contractor for this job. With our past project experience, there is no doubt that we can complete this project and hand over a quality product to the City of Craig

Duran & Pearce Contractors Inc. has been performing heavy civil work in Northwest Colorado since 1986. Duran & Pearce Contractors is a family owned, local contractor that has been fortunate to be in business for 35 years in Craig. For those 35 years, we have been an active and strong community partner and we look forward in continuing that for the many decades to come.

Duran & Pearce Contractors has an Experience Modification Rate of 0.88. Safety is the top priority for us, and our EMR proves that. We take great pride in not only our work but as well as the great relationships we have made with past clients and owners. We look forward in working with the City of Craig and continuing the relationship we have today.

I am willing to discuss all aspects of this project in more detail if we are the successful bidder. Please see the following information that SGM has requested.

Thank you,

*Derek Duran*

Derek Duran

Owner

[Derek.dpcontractors@gmail.com](mailto:Derek.dpcontractors@gmail.com)

970.629.8360 Cell

970.824.4014 Office



*"HELD TO A HIGHER STANDARD"*

## **PROJECT EXPERIENCE**

### **TRI-STATE G&T 30" RAW WATER LINE (PHASE 1 & 2)**

- **Owner:** Tri- State G&T                      Craig, Co
- **Role:** Subcontractor
- **Project Budget (D&P only):** Phase 1: \$225,000      Phase 2: \$295,000
- **Scope of Work:** Excavate for new 30" Steel Pipe. Excavation occurred 5' from pressurized 30" Raw Water Line. Projected consisted of excavating for nearly 2,500 LF of new line near highways and steep terrain. D&P provided shoring for deep excavations (15') and de-watering systems when working near the Yampa River. D&P excavated large bore pit and capture pit and provided support for boring company who bored for the 30" Pipeline under state highway 13.
- **Schedule:** Both Projects had 3-month schedules – Both being completed on time
- **Reference:** Bill Hesselgren, Project Manager. 970-326-5968 / Trevor Campbell

### **6" HDPE DUST SUPPRESSION SYSTEM**

- **Owner:** Tri- State G&T                      Craig, Co
- **Role:** General Contractor
- **Project Budget and Final Cost:** \$350,000.00
- **Scope of Work:** Excavate and install nearly 4,500 LF of 3", 4" and 6" HDPE pipe. Work included the following: Butt fusing and electro-fusing HDPE. Bore and pull pipe under Railroad Tracks and up steep terrain to Trapper Mine. Provide de-watering systems in deep excavations. Tie new system into existing system at Coal Handling Area
- **Schedule:** Project was completed on time within the 3-month time frame
- **Reference:** Bill Hesselgren, Project Manager. 970-326-5968



## *"HELD TO A HIGHER STANDARD"*

### **4",6"8" HDPE UTILITY PROJECT**

- **Owner:** TIC (The Industrial Company) Craig, Co
- **Role:** Subcontractor
- **Project Budget and Final Cost:** \$150,000.00
- **Scope of Work:** Excavate and install 1,000 LF of 3", 4" and 6" HDPE pipe. Work included the following: Butt fusing and electro-fusing HDPE. Provide de-watering systems. Provide shoring in deep excavated areas
- **Schedule:** Project was completed on time in a 3-month time frame
- **Reference:** Emmett Black, Project Manager. 208-940-0145

### **6" HDPE CASING (BORE UNDER RAILROAD TRACKS)**

- **Owner:** Tri- State G&T Craig, Co
- **Role:** General Contractor
- **Project Budget and Final Cost:** \$35,000.00
- **Scope of Work:** Butt fuse and provide 6" HDPE Casing for 3" Steel Waterline. Bore was approximately 250 LF below existing railroad tracks at 35' deep. Pulled 3" Waterline through and made (2) new tie-ins into existing pipeline
- **Schedule:** Project was completed on time in 10 days – Proposed schedule 14 days
- **Reference:** Dean Reid 970-824-4411

### **MEMORIAL REGIONAL HEALTH MOB EXPANSION**

- **Owner:** Memorial Regional Health General: Adena Company Craig, Co
- **Role:** Subcontractor
- **Project Budget (D&P Only):** \$1,350,000.00
- **Scope of Work:** Haul and install nearly 30,000 CY of fill, material. Provide installation of all sewer, water and storm sewer utilities (Approx. 2,500 LF). Site work and final grade work for concrete sidewalk and asphalt parking lot. Install and maintain all Erosion Control measures throughout duration of project. Provide Payment and Performance Bond
- **Schedule:** Total duration of Project 24 months
- **Reference:** Gary Teaters (Adena) 419-566-4313. Jennifer Riley (MRH) 970-756-4245



*"HELD TO A HIGHER STANDARD"*

**CRAIG RURAL FIRE PROTECTION DISTRICT APPARATUS BUILDING**

- **Owner:** Craig Rural Fire District Craig, Co
- **Role:** General Contractor
- **Project Budget (D&P Only):** \$1,300,000.00
- **Scope of Work:** General Contractor for new 10,000 SF Fire Apparatus Building. Work included utility line install, helical pile / concrete foundation install, site work for new concrete paved parking lot (250 CY). Manage all trades throughout project. Provide Payment and Performance Bond
- **Schedule:** 8 months – Work was completed in 8 months
- **Reference:** Chris Nichols 970-846-1815. KC Hume: 970-629-9048



*"HELD TO A HIGHER STANDARD"*

## **LIST of QUALIFIED SUBCONTRACTORS**

### ***DURAN & PEARCE CONTRACTORS: General Contractor / Excavation & Piping***

- Duran & Pearce Contractors will overlook the entire project. D&P will be performing all excavation, backfill, compaction, welding and installing all 6" pipeline. Provide support to all subcontractors and will provide and maintain erosion control measures as well as all de-watering

### ***DUCEY ELECTRIC: Electrical***

- Ducey Electric will be performing all electrical located in the pump house. De-energize existing pumps and provide all new electrical for the newly installed pumps. Ducey Electric joins the team with over 30 years' experience and has worked with the City of Craig on the Water Treatment upgrades as well as the Town of Rangley Water Plant / Sewer Plant upgrades.

### ***ELITE DRILLING COMPANY: Boring***

- Elite Drilling will be performing both bores (Yampa River and UPRR). Elite Drilling comes highly recommended by Ed McArthur; Owner of Native Excavating located in Steamboat Springs. Elite Drilling. Elite Drilling has experience drilling for 12" steel casing on the front range and have recently performed boring and direct drilling in Craig, Co working for YVEA

### ***MADSEN FABRICATION: Mechanical***

- Located in Craig, Co. Madsen fabrication will be disassembling and removing existing sludge pumps and will be install new sludge pumps and all pipe work involved in the pumphouse.

### ***FORBES WELDING SERVICES: Steel Casing***

- Located in Craig, Co. Forbes Welding Services will be performing all weld work on the 12" Steel Casing. Jay Forbes is a certified welder who has been in the industry for nearly 40 years. Past experience on oil and natural gas pipeline projects.

### ***ACTION SERVICES / DURAN & PEARCE CONTRACTORS: Sludge Haul***

- Action Services and D&P will be teaming up on the Sludge Haul
- Action Services is located on Craig, Co and has hauled the sludge for the City of Craig in the past and comes highly recommended



*"HELD TO A HIGHER STANDARD"*

## **SCHEDULE / PHASING**

If awarded the project, Duran & Pearce Contractors proposes to start the project Mid July 2020.

- Project Sequence: Phase 1B to 1A/ 1A to Phase 1
- Ox-Bow Area and Boring: To be completed in September 1<sup>st</sup> to October 1<sup>st</sup> projected schedule
- Project Complete: October 15<sup>th</sup>, Turnover to City of Craig: October 31<sup>st</sup>, 2020
- Duran & Pearce Contractors are aware of the Milestone Dates and as well as the liquidated damages. D&P is confident that the project will be completed and handed over to the City of Craig by October. If awarded the contract, D&P will be willing to provide a Detailed Project Schedule once it is known what phases are to be awarded.

### **PHASE 1B: Project Start**

IF awarded, work to begin in Mid-July

2 Week Duration

- Install approx. 1,500 LF of 6" DR9 HDPE Pipe
  - o Excavate, bed and compact new pipe
  - o Seeding / Erosion Control
  - o De-watering
  - o Provide survey as-builts
- Provide Sludge Removal throughout duration of Phase 1A
- Tie new 6" HDPE into existing 4" Sludge Line
- Initial Survey by owner
- All Compaction testing by Owner
- Disc existing wheat field – No Seeding

*Proposal is based off of all construction documents provided. Change in scope of work will result in change of project cost. Costs to be discussed and agreed upon prior to work continuing. If contractor is delayed due to unforeseen circumstances, then additional working days to be added to schedule.*



## *“HELD TO A HIGHER STANDARD”*

### **PHASE 1 A:**

**IF awarded, work to begin in Early August**

2 Week Duration

- Install approx. 950 LF of 6” DR9 HDPE Pipe
  - o Excavate, bed and compact new pipe
  - o Seeding / Erosion Control
  - o De-watering
  - o Provide survey as-builts
- Provide Sludge Removal throughout duration of Phase 1A
- Tie new 6” HDPE into existing 4” Sludge Line
- Initial Survey by owner
- All Compaction testing by Owner
- Provide construction fencing / barricades in open park area
- Assume portion of Loudy Simpson Park can be closed to the public throughout duration of 1A

*Proposal is based off of all construction documents provided. Change in scope of work will result in change of project cost. Costs to be discussed and agreed upon prior to work continuing. If contractor is delayed due to unforeseen circumstances, then additional working days to be added to schedule.*

### **PHASE 1:**

**IF awarded, work to begin in Mid / End of August**

6-8 Week Duration

Ox-Bow Work to start September 1<sup>st</sup> and be completed by October 1st

- Furnish and Install 2,730 LF of 6” DR9 HDPE Pipe
  - o Excavate, bed and compact new pipe
  - o Seeding / Erosion Control
  - o De-watering
  - o Provide survey as-builts
- Furnish and Install New Sludge Pumps



### ***“HELD TO A HIGHER STANDARD”***

- Demo and Remove electrical to pumps, existing pumps and misc. piping
- Bore Under Yampa River and UPRR ROW
  - o Pricing for installation as per the provided geotechnical investigation. If boring refusal, substantial cobble or gravels are encountered, casing and or pipe ramming equipment maybe required at additional cost. Additional costs to occur if material is other than that identified through the soil investigation
  - o Proposal does not include solid rock (mud motor) drilling
- Proposal includes price of UPRR Construction Observation Fees and Flaggers
- Provide Sludge Removal throughout duration of Phase 1
- Tie new 6” HDPE into existing 4” Sludge Line
- Initial Survey by owner
- All Compaction testing by Owner

*Proposal is based off of all construction documents provided. Change in scope of work will result in change of project cost. Costs to be discussed and agreed upon prior to work continuing. If contractor is delayed due to unforeseen circumstances, then additional working days to be added to schedule.*

### **RELEVANT INFORMATION**

As mentioned earlier, Duran & Pearce Contractors is a locally owned company located in Craig, Co. We have been in business for nearly 35 years and have been fortunate to perform work in NW Colorado for those 35 years. On this particular project, Duran & Pearce Contractors insists to use as many local resources as possible. It is important to us to stay local and take pride in the fact that we are strong community partner. Over the past 35 years, Duran & Pearce Contractors has sponsored and supported any programs and events such as:

- **Youth Sports:** Doak Walker Football, Youth Soccer, Youth Basketball and Tee-Ball
- **Community Events:** Boys and Girls Club Annual Cowboy Christmas, City of Craig Whittle the Wood, Young Life Golf Tournament
- **Education & Athletics:** Friends of Moffat County Education Program, MCHS Athletics Booster Club Member

It is safe to say that Duran & Pearce Contractors will continue to support the City of Craig and the great community we are proud to be a part of.





*"HELD TO A HIGHER STANDARD"*

## Exhibit D: RCD Bid Package

## SECTION 00310

## BID FORM

2020 SLUDGE HANDLING IMPROVEMENTS - PHASE 1  
CITY OF CRAIGTo: City of Craig 300 West 4th Street  
Craig, CO 81625

The undersigned Bidder, having familiarized himself with the Work required by the Contract Documents, the site where the Work is to be performed, local labor conditions and all laws, regulations and other factors affecting performance of the Work, and having satisfied himself of the expense and difficulties attending performance of the Work, RCD Construction, Inc.

(Bidder) hereby proposes and agrees, if this Bid is accepted, to enter into Agreement in the form attached to perform all Work, including the assumption of all obligations, duties and responsibilities necessary to the successful completion of the Contract and the furnishing of all materials and equipment required to be incorporated in and Form a permanent part of the specified Work; tools, equipment, supplies, transportation, facilities, labor, superintendence and services required to perform the specified Work and Bonds, insurance and submittals; all as indicated or specified in the Contract Documents to be performed or furnished by Contractor for the following lump sum and unit prices:

**BASE BID**

Item	Description	Quantity	Unit	Unit Price	Amount
1	Installation of New Sludge Pumps	2	Each	<u>\$48,800.00</u>	<u>\$97,600.00</u>
2	Installation of 6" DR9 (250 psi) DIPS HDPE sludge line				
		2730	L.F	<u>\$38.80</u>	<u>\$105,924.00</u>
3	Existing system tie-ins	2	Each	<u>\$13,000.00</u>	<u>\$28,000.00</u>
4	Bore under Yampa River	1	Each	<u>\$45,905.00</u>	<u>\$45,905.00</u>
5	Bore under UPRR ROW	1	Each	<u>\$67,000.00</u>	<u>\$67,000.00</u>
6	Provide Sludge Removal	1,470,000	\$/gallon	<u>\$.051</u>	<u>\$74,970.00</u>
7	Mobilization/Demobilization	1	Each	<u>\$38,000.00</u>	<u>\$38,000.00</u>

Total : \$457,399.00





**TOTAL BASE BID**(Words) FOUR HUNDRED FIFTY SEVEN THOUSAND THREE HUNDRED NINETY NINE AND ZERO

8	Bid Alternate A – Primary Extension	Each	<u>1</u>	<u>\$52,099.60</u>
9	Bid Alternate B – Secondary Extension	Each	<u>1</u>	<u>\$58,200.00</u>

Bid Items 8 and 9 are to include sludge removal and mobilization/demobilization for the primary and secondary extensions in their respective prices.

The undersigned Bidder agrees to furnish any required Bonds, all materials, and to enter into a contract within the time specified in the Instruction to Bidders and further agrees to complete all Work covered by the Bid, in accordance with specified requirements, within the time specified in the Agreement.

Receipt of copies of the following addendum(a) is hereby acknowledged and have been considered in preparation of this Bid.

<u>Addendum No.</u>	<u>Bidders Signature</u>	<u>Date Acknowledged</u>
1		06/11/2020
2		06/11/2020
3		06/11/2020
4		06/11/2020

Enclosed herewith is the required bid security in the amount of 5% Dollars (\$          ) which the undersigned Bidder agrees is to be forfeited to and become the property of Owner, as liquidated damages, should this Bid be accepted and a contract be awarded to him and he fail to enter into a contract in the form prescribed and to furnish the required Bonds within the time specified on the Instructions to Bidders, but otherwise the bid security will be returned upon his signing this contract and delivering the Bonds.

In submitting this Bid it is understood that the right is reserved by Owner to reject any and all bids, and it is understood that this Bid may not be withdrawn during a period of 60 days after the scheduled time for the receipt of bids.

The undersigned Bidder hereby certifies (a) that this Bid is genuine and is not made in the interest of, or in the behalf of, any undisclosed person, firm, or corporation, and is not submitted in conformity with any agreement or rules of any group, association, organization, or corporation; (b) that he has not directly or indirectly induced or solicited any other Bidder to put in a false or sham Bid; (c) that he has not solicited or induced any person, firm, or corporation to refrain from bidding; and (d) that he has not sought by collusion to obtain for himself any advantage over any other Bidder or over the Owner.

The Bidder (has) (has not) previously performed work subject to Executive Order 11246.

The full names and addresses of parties interested in this Bid as principals are as follows:

SIGNATURE OF BIDDER:

Date: 06/11/2020

If an Individual: \_\_\_\_\_, doing business as \_\_\_\_\_

If a Partnership: \_\_\_\_\_ by \_\_\_\_\_  
\_\_\_\_\_, partner

If a Corporation: RCD Construction, Inc. a S-Corporation Corporation)

by Ryan Domson - 

(SEAL & TITLE \_\_\_\_\_ ATTEST)

Business Address of Bidder 150 N. 2nd St. Hayden CO, 81639

If a Bidder is a joint venture, other party must sign below.

Date: \_\_\_\_\_

If an Individual: \_\_\_\_\_, doing business as \_\_\_\_\_

If a Partnership: by partner \_\_\_\_\_

If a Corporation: by Ryan Domson - President

(SEAL & TITLE \_\_\_\_\_ ATTEST)

Business Address of Bidder 150 N. 2nd St. Hayden CO, 81639

END OF SECTION

### PROPOSED SUBCONTRACTORS

The proposal is based on subcontracting certain major portions of the Work to subcontractors as listed below:

SUBCONTRACTOR	ITEM / DESCRIPTION OF WORK
Camblin Inc. Kenetic	Pipe welding boring

### SCHEDULE OF MAJOR MATERIAL SUPPLIERS

ITEM / DESCRIPTION	MANUFACTURER OR SUPPLIER
Cor & Main	Pipe

Note: In connection with the major items of equipment to be furnished and installed, the Bidder does expressly agree to the following provision:

Should the Bidder indicate more than one manufacturer, or fail to indicate a manufacturer, the Owner shall have the specific right to make the selection at no additional cost to the Owner.



**BID BOND****TRAVELERS CASUALTY AND SURETY COMPANY OF AMERICA**  
Hartford, Connecticut 06183

KNOWN ALL BY THESE PRESENTS, That we, RCD Construction, Inc., as Principal, and Travelers Casualty and Surety Company of America, as Surety, are held and firmly bound unto City of Craig, as Obligee, in the sum of Five Percent of Bid Amount Dollars (\$5%) for the payment of which we bind ourselves, and our successors and assigns, jointly and severally, as provided herein.

WHEREAS, Principal has submitted or is about to submit a bid to the Obligee on a contract for 2020 Sludge Handling Improvements-Phase I ("Project").

NOW, THEREFORE, the condition of this bond is that if Obligee accepts Principal's bid, and Principal enters into a contract with Obligee in conformance with the terms of the bid and provides such bond or bonds as may be specified in the bidding or contract documents, then this obligation shall be void; otherwise Principal and Surety will pay to Obligee the difference between the amount of Principal's bid and the amount for which Obligee shall in good faith contract with another person or entity to perform the work covered by Principal's bid, but in no event shall Surety's and Principal's liability exceed the penal sum of this bond.

Signed this 9th day of June, 2020.

**RCD Construction, Inc**

(Principal)

By: 

Ryan Domson, President

Travelers Casualty and Surety Company of America

By: 

Darren Coltrinari, Attorney-in-Fact





**Travelers Casualty and Surety Company of America  
Travelers Casualty and Surety Company  
St. Paul Fire and Marine Insurance Company**

**POWER OF ATTORNEY**

**KNOW ALL MEN BY THESE PRESENTS:** That Travelers Casualty and Surety Company of America, Travelers Casualty and Surety Company, and St. Paul Fire and Marine Insurance Company are corporations duly organized under the laws of the State of Connecticut (herein collectively called the "Companies"), and that the Companies do hereby make, constitute and appoint **Darren Coltrinar** of **Grand Junction Colorado**, their true and lawful Attorney-in-Fact to sign, execute, seal and acknowledge any and all bonds, recognizances, conditional undertakings and other writings obligatory in the nature thereof on behalf of the Companies in their business of guaranteeing the fidelity of persons, guaranteeing the performance of contracts and executing or guaranteeing bonds and undertakings required or permitted in any actions or proceedings allowed by law.

**IN WITNESS WHEREOF**, the Companies have caused this instrument to be signed, and their corporate seals to be hereto affixed, this **3rd** day of **February**, **2017**.



State of Connecticut

City of Hartford ss.


By:   
Robert L. Raney, Senior Vice President

On this the **3rd** day of **February**, **2017**, before me personally appeared **Robert L. Raney**, who acknowledged himself to be the Senior Vice President of Travelers Casualty and Surety Company of America, Travelers Casualty and Surety Company, and St. Paul Fire and Marine Insurance Company, and that he, as such, being authorized so to do, executed the foregoing instrument for the purposes therein contained by signing on behalf of the corporations by himself as a duly authorized officer.

**In Witness Whereof**, I hereunto set my hand and official seal.

My Commission expires the **30th** day of **June**, **2021**



  
Marie C. Tetreault, Notary Public

This Power of Attorney is granted under and by the authority of the following resolutions adopted by the Boards of Directors of Travelers Casualty and Surety Company of America, Travelers Casualty and Surety Company, and St. Paul Fire and Marine Insurance Company, which resolutions are now in full force and effect, reading as follows:

**RESOLVED**, that the Chairman, the President, any Vice Chairman, any Executive Vice President, any Senior Vice President, any Vice President, any Second Vice President, the Treasurer, any Assistant Treasurer, the Corporate Secretary or any Assistant Secretary may appoint Attorneys-in-Fact and Agents to act for and on behalf of the Company and may give such appointee such authority as his or her certificate of authority may prescribe to sign with the Company's name and seal with the Company's seal bonds, recognizances, contracts of indemnity, and other writings obligatory in the nature of a bond, recognizance, or conditional undertaking, and any of said officers or the Board of Directors at any time may remove any such appointee and revoke the power given him or her; and it is

**FURTHER RESOLVED**, that the Chairman, the President, any Vice Chairman, any Executive Vice President, any Senior Vice President or any Vice President may delegate all or any part of the foregoing authority to one or more officers or employees of this Company, provided that each such delegation is in writing and a copy thereof is filed in the office of the Secretary; and it is


**FURTHER RESOLVED**, that any bond, recognizance, contract of indemnity, or writing obligatory in the nature of a bond, recognizance, or conditional undertaking shall be valid and binding upon the Company when (a) signed by the President, any Vice Chairman, any Executive Vice President, any Senior Vice President or any Vice President, any Second Vice President, the Treasurer, any Assistant Treasurer, the Corporate Secretary or any Assistant Secretary and duly attested and sealed with the Company's seal by a Secretary or Assistant Secretary; or (b) duly executed (under seal, if required) by one or more Attorneys-in-Fact and Agents pursuant to the power prescribed in his or her certificate or their certificates of authority or by one or more Company officers pursuant to a written delegation of authority; and it is

**FURTHER RESOLVED**, that the signature of each of the following officers: President, any Executive Vice President, any Senior Vice President, any Vice President, any Assistant Vice President, any Secretary, any Assistant Secretary, and the seal of the Company may be affixed by facsimile to any Power of Attorney or to any certificate relating thereto appointing Resident Vice Presidents, Resident Assistant Secretaries or Attorneys-in-Fact for purposes only of executing and attesting bonds and undertakings and other writings obligatory in the nature thereof, and any such Power of Attorney or certificate bearing such facsimile signature or facsimile seal shall be valid and binding upon the Company and any such power so executed and certified by such facsimile signature and facsimile seal shall be valid and binding on the Company in the future with respect to any bond or understanding to which it is attached.

I, **Kevin E. Hughes**, the undersigned, Assistant Secretary of Travelers Casualty and Surety Company of America, Travelers Casualty and Surety Company, and St. Paul Fire and Marine Insurance Company, do hereby certify that the above and foregoing is a true and correct copy of the Power of Attorney executed by said Companies, which remains in full force and effect.

Dated this 9th day of June, 2020



  
Kevin E. Hughes, Assistant Secretary

**To verify the authenticity of this Power of Attorney, please call us at 1-800-421-3880.  
Please refer to the above-named Attorney-in-Fact and the details of the bond to which the power is attached.**





**ADDENDUM ORDER**

ORDER NO. 1  
DATE: 5/27/2020  
BID DATE: 06/11/2020

NAME OF PROJECT: 2020 Sludge Handling Improvements – Phase 1  
OWNER: City of Craig  
ENGINEER: SGM

The following changes are hereby made to the **CONTRACT DOCUMENTS**:

**Clarifications**

N/A

**Specifications**

N/A

**Drawings**

N/A

  
Name

6/11/2020  
Date

**PREPARED BY:**

**Chad Paulson, P.E., Alex Kordick, P.E.**  
**SGM**

**List of Attachments:**

- **Geotechnical Investigation, Sludge Line – Yampa River/Railroad Bore, May 14, 2020**



**ADDENDUM ORDER**

ORDER NO. 2  
DATE: 6/01/2020  
BID DATE: 06/11/2020

NAME OF PROJECT: 2020 Sludge Handling Improvements – Phase 1  
OWNER: City of Craig  
ENGINEER: SGM

The following changes are hereby made to the **CONTRACT DOCUMENTS**:

**Clarifications**


N/A

**Specifications**

N/A

**Drawings**

N/A

  
Name

6/11/2020  
Date

**PREPARED BY:**

**Chad Paulson, P.E., Alex Kordick, P.E.**  
**SGM**

**List of Attachments:**

- Rail Pro Construction Observation Requirements
- Rail Pro Construction Observation Costs
- Track and Ground Monitoring Guideline
- Rail Pro Flagger Costs
- Work Plan Form

## ADDENDUM ORDER

ORDER NO. 3  
DATE: 06/02/10  
BID DATE: 06/11/20

NAME OF PROJECT: 2020 Sludge Handling Improvements – Phase 1  
OWNER: City of Craig  
ENGINEER: SGM

The following changes are hereby made to the **CONTRACT DOCUMENTS**:

### Clarifications

1. Sign-in sheet from mandatory Pre-bid meeting conducted at the WWTF site attached.
2. Substantial completion of project is set for October 15, 2020.
3. The September 1<sup>st</sup> constraint for beginning of work in section 1b, has been removed.
4. The contractor is responsible for sludge removal while the pipeline is inoperable. The contractor can haul the sludge, dewater on site, or install a temporary pipeline, see clarification note 14 below.
5. The existing 4" sludge line can be removed or abandoned in place as installation of new 6" line necessitates.
6. The Moffat County Landfill will accept, at no cost to the contractor, removed portions of the existing 4" PVC sludge Line with no dirt or debris in the pipe, residue is acceptable.
7. New pipe can be open cut or bored at the contractor's preference, in locations that allow boring; not all segments are suitable for boring.
8. The City will flush the existing sludge line for contractor.
9. The work segment on the ox-bow, between the river and the railroad, shall be bedded using excavated onsite materials, appropriately screened if necessary, to exclude materials larger than 2". The remainder of the project shall be bedded as specified. The City acknowledges that areas of the project may have suitable native materials. City will consider approval of native materials in lieu of import on a case-by-case basis. Any use native material outside of ox-bow segment must be approved by City.
10. The City has specified that the contractor will be able to stage equipment and materials on the Waste Water Treatment Facility property, any construction easement, and county ground where the alignment passes. All disturbed areas will have to be repaired by the contractor.
11. Excess fill must be removed from the site at the contractor's expense.
12. Topsoil can only be stripped to facilitate the excavation of open cut for pipe placement. Topsoil to be returned to match existing profile depths.
13. The specs (02200-6) call for 4" of topsoil in disturbed areas, if stockpiled material is insufficient, topsoil would need to be imported.
14. A temporary sludge line can be installed by the contractor and run above ground; the temporary line would need to be 4" min rated for 250-psi- operation.
15. The seed mixes can be found on the general notes page of the plans the seeding spec is 02936.
16. The minimum awarded contract will be contract 1A from the facility to the southern end of the RR ROW. If a contractor choses to also perform section 1B or 1C they can

proceed with any section according to their schedule but MUST complete the work in the oxbow during between Sept. 1 to Oct. 1. Payment will be by section but not completing section 1A is a breach of contract. Sludge line will need to be drained and flushed before every pipe cut.

17. The Owner will provide horizontal and vertical control at the WWTF site for contractor use, consisting of three locations. The Owner will stake both sides of the temporary construction easements on the Mack property at 50 ft intervals. The Owner will provide one-time construction staking of pipe centerline, consisting of locates at all changes in alignment, bore ends, valves and various points-on-line to establish general profile at spacing not to exceed 200 ft. apart. Any additional survey or re-survey of Owner provided locations is the responsibility of the contractor. A licensed surveyor is not mandatory for collection of as-built survey information. However, if a licensed surveyor is not being used, Contractor must demonstrate to Owner that their proposed method is suitably accurate to meet the needs of as-built information prior to start of construction.
18. Trees and other brush debris must be removed from the site, the landfill will charge the contractor for disposal of any materials except the existing 4" sludge line.
19. The contractor must furnish the pumps.
20. The owner will pay for all field tests, and lists required tests (02200-16).

#### Specifications


- 00020 Invitation to bid**, Addition of substantial completion date. Base Contract, Alternative A and Alternative B modified to include sludge removal. New document attached.
- 00310 Bid Form**, Base Bid numbering error corrected, Item 6- Provide Sludge Removal, and Item 7 Mobilization/Demobilization added. New document attached.
- 00510 Agreement**, Substantial completion date added to agreement; the new document is attached.
- 01010 Summary of Work**, Base Contract, Alternative A and Alternative B modified to include sludge removal. New document attached.
- 01025 Measurement and Payment**, Removal of sludge hauling from unit price list of Bid Item 3, addition of Bid Item 6- Provide Sludge Removal, and Bid Item 7 Mobilization/Demobilization added. New document attached.

#### Drawings

**2- General Notes:** Note 8.- typo corrected, Note 18.- deleted time constraint in section 1B limiting work to after September 1' Note 21.- Updated with new sludge quantities. New Note added: Note 22. States contractor to coordinate with City to flush the existing sludge line. Note 28 deleted- redundant to note 41, contractor to provide survey grade 3-d locates every 20' and at all significant features. Note 40 deleted, redundant to note 20 contractor responsible for fees and coordination of work in RR ROW with Rail Pros. Notes 40 to 42 added.

**13-Sludge Pump Notes and Details:** Corrected Note 7 for correct pump model NM105BY02S14V.2

**ADDENDUM #1<sup>3</sup> ACKNOWLEDGED BY:**

  
\_\_\_\_\_  
Name

  
\_\_\_\_\_  
Date

**PREPARED BY:**

**Chad Paulson, P.E., Alex Kordick, P.E.  
SGM**

---

***List of Attachments:***

*Specs 00020, 00310, 00510, 01010, 0125*

*Pre-bid sign in sheet*

*Drawings 2 and 13*



SECTION 00020  
INVITATION TO BID  
2020 SLUDGE HANDLING IMPROVMENTS- PHASE 1

City of Craig  
300 West 4th Street Craig, CO 81625  
970-824-8151

Sealed bids for Phase 1 of the 2020 Sludge Line Improvements project will be received by the City of Craig at 300 West 4th Street, Craig, 81625 until 2:00 PM local time, June 11, 2020. Bids received after this time will not be accepted and will be returned unopened. At said place and time, and promptly thereafter, all bids that have been duly received will be publicly opened and read aloud. All interested parties are invited to attend.

The Project is to be fully completed by October 31, 2020, with substantial completion by October 15, 2020.

The Work of this Contract generally consists of the following system improvements, to be completed one at a time in the order listed:

**Base Contract**

Replace existing sludge pumps and appurtenances at WWTF. Replace existing 4" PVC sludge line from WWTF to UPRR ROW (South end) with 6" DR9 (250 psi) DIPS HDPE, approximately 2,700 linear feet. Replace existing 4" PVC sludge line in UPRR ROW with 6" Restrained Joint TR Flex Class 350 DIP or engineer approved equal, cased in 12" ASTM A53 Grade B seamless steel pipe, approximately 232 linear feet. Replace existing 4" PVC sludge line from UPRR ROW (North end) with 6" DR9 (250 psi) DIPS HDPE for approximately 30 linear feet and tie-in to existing 4" PVC sludge line. Bore under UPRR ROW and Yampa River. Provide sludge removal from sludge basin at the WWTF every Monday, Wednesday and Friday during period when sludge line is inoperable. Sludge may be hauled to the Cities Sludge Drying facility, or contractor may coordinate with WWTF staff to dewater sludge on-site then haul to drying facility.

**Alternative A**

Replace an additional approximately 920 linear feet of existing 4" PVC sludge line with 6" DR9 (250 psi) DIPS HDPE from end of Base Contract location and tie-in to existing 4" PVC sludge line. Provide sludge removal from sludge basin at the WWTF every Monday, Wednesday and Friday during period when sludge line is inoperable.

**Alternative B**

Replace an additional approximately 1,500 linear feet of existing 4" PVC sludge line with 6" DR9 (250 psi) DIPS HDPE from end Alternative A contract location and tie-in to existing 4" PVC sludge line. Provide sludge removal from sludge basin at the WWTF every Monday, Wednesday and Friday during period when sludge line is inoperable.

Work on this contract will include the removal and/or abandonment of existing sludge line and as needed to perform the work. Seeding, cleanup and restoration of disturbed areas will also be

required.

Bids shall be on a combination of lump sum and unit price basis.

Bidding documents will be available by May 21, 2020.

Electronic copies of the Bidding Documents for use in preparing Bids may be obtained from the engineer, SGM, at no cost by contacting Joan Preisner at (970) 945-1004 or [joanp@sgm-inc.com](mailto:joanp@sgm-inc.com).

A copy of Bidding Documents will be available for examination the office of the City of Craig, 300 West 4th Street, Craig, CO 81625.

All questions concerning bid shall be direct to engineer by contacting Chad Paulson at (970) 945-1004 or [chadp@sgm-inc.com](mailto:chadp@sgm-inc.com).

A mandatory pre-bid conference will be held on May 28<sup>th</sup> at place identified in the Instructions to Bidders. One representative from each bidder is allowed to attend.

Each Bidder shall file with his bid a bid security in the form of a cashier's check, certified check or a bidder's bond in accordance with the Instructions to Bidders.

The Bidder to whom a Contract is awarded will be required to furnish a Performance Bond guaranteeing faithful performance and a Labor and Material Payment Bond guaranteeing payment of all debts arising out of the Work.

No Bid may be withdrawn for the period of time after the date Bids are opened which is specified in the Bid Form.

The City of Craig reserves the right to reject any or all Bids, and to waive any informalities or irregularities therein.

Signed By

\_\_\_\_\_  
City of Craig

END OF SECTION



## ADDENDUM ORDER

ORDER NO. 4  
DATE: 6/8/2020  
BID DATE: 6/11/2020

NAME OF PROJECT: 2020 Sludge Handling Improvements – Phase 1  
OWNER: City of Craig  
ENGINEER: SGM

The following changes are hereby made to the **CONTRACT DOCUMENTS**:

### Clarifications

1. The carrier pipe must be seamless, Steel ASTM A53 grade B, minimum yield strength of 35,000psi, minimum 1/4" wall thickness. (Railroad dictated material, yield strength, and min. thickness). The RR does not designate any required coatings, please refer back to the City's Public works manual with requires protection from corrosion by the use of an approved bituminous coating.
2. The City has paid the UPRR permit costs, the contractor is only liable for the costs incurred from work with RailPros. The use of RailPros is a condition of the UPRR contract.
3. General Notes Sheet 2 Table 2-Craig Sludge Line Wetlands Seed Mix Clarifications:
  - a. Spearleaf Rabbit Brush wildland collected refers to plants not obtained from a national nursery catalogue, but instead locally sourced, or collected (collected from local rabbit brush seed).
  - b. Coyote Willow locally available stem cuts; "Stems refer to containerized willows or bare willow wands.

The following documents have been included to the contract documents to better define the project.

1. Specification 02224-Boring and Jacking


### Specifications

**Specification 02224-Boring and Jacking**, new specification added to address casing pipe welding specifications.

### Drawings

N/A

### ADDENDUM #4 ACKNOWLEDGED BY:

  
Name

  
Date

### PREPARED BY:

Chad Paulson, P.E., Alex Kordick,



**P.E.**  
**SGM**

---

**List of Attachments:**

- **02224-Boring and Jacking**

OFFICE OF THE SECRETARY OF STATE  
OF THE STATE OF COLORADO

**CERTIFICATE OF FACT OF GOOD STANDING**

I, Jena Griswold, as the Secretary of State of the State of Colorado, hereby certify that, according to the records of this office,

RCD Construction Inc

is a

Corporation

formed or registered on 02/07/2014 under the law of Colorado, has complied with all applicable requirements of this office, and is in good standing with this office. This entity has been assigned entity identification number 20141089221 .

This certificate reflects facts established or disclosed by documents delivered to this office on paper through 03/19/2020 that have been posted, and by documents delivered to this office electronically through 03/20/2020 @ 14:54:31 .

I have affixed hereto the Great Seal of the State of Colorado and duly generated, executed, and issued this official certificate at Denver, Colorado on 03/20/2020 @ 14:54:31 in accordance with applicable law. This certificate is assigned Confirmation Number 12161619 .



*Jena Griswold*

Secretary of State of the State of Colorado

\*\*\*\*\*End of Certificate\*\*\*\*\*

Notice: A certificate issued electronically from the Colorado Secretary of State's Web site is fully and immediately valid and effective. However, as an option, the issuance and validity of a certificate obtained electronically may be established by visiting the Validate a Certificate page of the Secretary of State's Web site, <http://www.sos.state.co.us/biz/CertificateSearchCriteria.do> entering the certificate's confirmation number displayed on the certificate, and following the instructions displayed. Confirming the issuance of a certificate is merely optional and is not necessary to the valid and effective issuance of a certificate. For more information, visit our Web site, <http://www.sos.state.co.us/> click "Businesses, trademarks, trade names" and select "Frequently Asked Questions."

# City of Craig, Colorado

CONTRACTOR'S LICENSE NO. 2499

BE IT KNOWN THAT

DBA

RYAN DAWSON

RED CONSTRUCTION, INC

having paid the Building Department of the City of Craig, Colorado the sum of \$ 200-

Dollars, is hereby granted this license to engage in the following

classification(s) of construction:

BASE EXCAVATION

SK-SC CONCRETE

This license is issued and is revocable under the provisions of the Ordinances of the City of Craig, Colorado, and shall be in effect until the 23 day of Sept, 2020 subject to such Ordinances.

Given under my hand and seal the 23 day of Sept, 2019.

(SEAL)

MARLYN BEUHOF

Building Official

## Exhibit E: Duran and Pearce Bid Package



## SECTION 00310

## BID FORM

2020 SLUDGE HANDLING IMPROVEMENTS - PHASE 1  
CITY OF CRAIG

To: City of Craig 300 West 4th Street  
Craig, CO 81625

The undersigned Bidder, having familiarized himself with the Work required by the Contract Documents, the site where the Work is to be performed, local labor conditions and all laws, regulations and other factors affecting performance of the Work, and having satisfied himself of the expense and difficulties attending performance of the Work, DURAN + PEARCE CONTRACTORS, INC (Bidder) hereby proposes and agrees, if this Bid is accepted, to enter into Agreement in the form attached to perform all Work, including the assumption of all obligations, duties and responsibilities necessary to the successful completion of the Contract and the furnishing of all materials and equipment required to be incorporated in and Form a permanent part of the specified Work; tools, equipment, supplies, transportation, facilities, labor, superintendence and services required to perform the specified Work and Bonds, insurance and submittals; all as indicated or specified in the Contract Documents to be performed or furnished by Contractor for the following lump sum and unit prices:

**BASE BID**

Item	Description	Quantity	Unit	Unit Price	Amount
1	Installation of New Sludge Pumps	2	Each	<u>60,500-</u>	<u>121,000-</u>
2	Installation of 6" DR9 (250 psi) DIPS HDPE sludge line	2730	L.F	<u>65.75</u>	<u>179,477.50</u>
3	Existing system tie-ins	2	Each	<u>4,000-</u>	<u>8,000</u>
4	Bore under Yampa River	1	Each	<u>57,750-</u>	<u>57,750</u>
5	Bore under UPRR ROW	1	Each	<u>82,500-</u>	<u>82,500-</u>
6	Provide Sludge Removal	<u>696,000</u>	\$/gallon	<u>.065</u>	<u>45,240</u>
7	Mobilization/Demobilization	1	Each	<u>42,035-</u>	<u>42,035</u> → <u>42,035.-</u>

TOTAL BASE BID 536,022.50

(Words) Five Hundred & Thirty Six Thousand, & Twenty Two + <sup>00</sup>/<sub>100</sub> Dollars

8	Bid Alternate A – Primary Extension	Each	<u>1</u>	<u>95,000.-</u>
9	Bid Alternate B – Secondary Extension	Each	<u>1</u>	<u>68,000.-</u>

Bid Items 8 and 9 are to include sludge removal and mobilization/demobilization for the primary and secondary extensions in their respective prices.

The undersigned Bidder agrees to furnish any required Bonds, all materials, and to enter into a contract within the time specified in the Instruction to Bidders and further agrees to complete all Work covered by the Bid, in accordance with specified requirements, within the time specified in the Agreement.

Receipt of copies of the following addendum(a) is hereby acknowledged and have been considered in preparation of this Bid.

<u>Addendum No.</u>	<u>Bidders Signature</u>	<u>Date Acknowledged</u>
<u>No. 1</u>	<u>[Signature]</u>	<u>5-30-20</u>
<u>No. 2</u>	<u>[Signature]</u>	<u>6-3-20</u>
<u>No. 3</u>	<u>[Signature]</u>	<u>6-5-20</u>
<u>No. 4</u>	<u>[Signature]</u>	<u>6-9-20</u>

Enclosed herewith is the required bid security in the amount of Twenty Nine Thousand & five Hundred Dollars (\$ 29,500.-) which the undersigned Bidder agrees is to be forfeited to and become the property of Owner, as liquidated damages, should this Bid be accepted and a contract be awarded to him and he fail to enter into a contract in the form prescribed and to furnish the required Bonds within the time specified on the Instructions to Bidders, but otherwise the bid security will be returned upon his signing this contract and delivering the Bonds.

In submitting this Bid it is understood that the right is reserved by Owner to reject any and all bids, and it is understood that this Bid may not be withdrawn during a period of 60 days after the scheduled time for the receipt of bids.

The undersigned Bidder hereby certifies (a) that this Bid is genuine and is not made in the interest of, or in the behalf of, any undisclosed person, firm, or corporation, and is not submitted in conformity with any agreement or rules of any group, association, organization, or corporation; (b) that he has not directly or indirectly induced or solicited any other Bidder to put in a false or sham Bid; (c) that he has not solicited or induced any person, firm, or corporation to refrain from bidding; and (d) that he has not sought by collusion to obtain for himself any advantage over any other Bidder or over the Owner.

The Bidder (has) (has not) previously performed work subject to Executive Order 11246.



**ADDENDUM ORDER**

ORDER NO. 1  
DATE: 5/27/2020  
BID DATE: 06/11/2020

NAME OF PROJECT: 2020 Sludge Handling Improvements – Phase 1

OWNER: City of Craig

ENGINEER: SGM

The following changes are hereby made to the **CONTRACT DOCUMENTS**:

**Clarifications**

N/A

**Specifications**

N/A

**Drawings**

N/A

DEREK DURAN

Name

5-30-20

Date

**PREPARED BY:**

Chad Paulson, P.E., Alex Kordick, P.E.  
SGM

**List of Attachments:**

- Geotechnical Investigation, Sludge Line – Yampa River/Railroad Bore, May 14, 2020



**ADDENDUM ORDER**

ORDER NO. 2  
DATE: 6/01/2020  
BID DATE: 06/11/2020

NAME OF PROJECT: 2020 Sludge Handling Improvements – Phase 1

OWNER: City of Craig

ENGINEER: SGM

The following changes are hereby made to the CONTRACT DOCUMENTS:

**Clarifications**

N/A

**Specifications**

N/A

**Drawings**

N/A

Derek Duran  
Name

6-3-20  
Date

**PREPARED BY:**

Chad Paulson, P.E., Alex Kordick, P.E.  
SGM

**List of Attachments:**

- Rail Pro Construction Observation Requirements
- Rail Pro Construction Observation Costs
- Track and Ground Monitoring Guideline
- Rail Pro Flagger Costs
- Work Plan Form



## ADDENDUM ORDER

ORDER NO.	3
DATE:	06/02/10
BID DATE:	06/11/20

NAME OF PROJECT: 2020 Sludge Handling Improvements – Phase 1

OWNER: City of Craig

ENGINEER: SGM

The following changes are hereby made to the CONTRACT DOCUMENTS:

### Clarifications

1. Sign-in sheet from mandatory Pre-bid meeting conducted at the WWTF site attached.
2. Substantial completion of project is set for October 15, 2020.
3. The September 1<sup>st</sup> constraint for beginning of work in section 1b, has been removed.
4. The contractor is responsible for sludge removal while the pipeline is inoperable. The contractor can haul the sludge, dewater on site, or install a temporary pipeline, see clarification note 14 below.
5. The existing 4" sludge line can be removed or abandoned in place as installation of new 6" line necessitates.
6. The Moffat County Landfill will accept, at no cost to the contractor, removed portions of the existing 4" PVC sludge Line with no dirt or debris in the pipe, residue is acceptable.
7. New pipe can be open cut or bored at the contractor's preference, in locations that allow boring; not all segments are suitable for boring.
8. The City will flush the existing sludge line for contractor.
9. The work segment on the ox-bow, between the river and the railroad, shall be bedded using excavated onsite materials, appropriately screened if necessary, to exclude materials larger than 2". The remainder of the project shall be bedded as specified. The City acknowledges that areas of the project may have suitable native materials. City will consider approval of native materials in lieu of import on a case-by-case basis. Any use native material outside of ox-bow segment must be approved by City.
10. The City has specified that the contractor will be able to stage equipment and materials on the Waste Water Treatment Facility property, any construction easement, and county ground where the alignment passes. All disturbed areas will have to be repaired by the contractor.
11. Excess fill must be removed from the site at the contractor's expense.
12. Topsoil can only be stripped to facilitate the excavation of open cut for pipe placement. Topsoil to be returned to match existing profile depths.
13. The specs (02200-6) call for 4" of topsoil in disturbed areas, if stockpiled material is insufficient, topsoil would need to be imported.
14. A temporary sludge line can be installed by the contractor and run above ground; the temporary line would need to be 4" min rated for 250-psi- operation.
15. The seed mixes can be found on the general notes page of the plans the seeding spec is 02936.
16. The minimum awarded contract will be contract 1A from the facility to the southern end of the RR ROW. If a contractor choses to also perform section 1B or 1C they can

proceed with any section according to their schedule but MUST complete the work in the oxbow during between Sept. 1 to Oct. 1. Payment will be by section but not completing section 1A is a breach of contract. Sludge line will need to be drained and flushed before every pipe cut.

17. The Owner will provide horizontal and vertical control at the WWTF site for contractor use, consisting of three locations. The Owner will stake both sides of the temporary construction easements on the Mack property at 50 ft intervals. The Owner will provide one-time construction staking of pipe centerline, consisting of locates at all changes in alignment, bore ends, valves and various points-on-line to establish general profile at spacing not to exceed 200 ft. apart. Any additional survey or re-survey of Owner provided locations is the responsibility of the contractor. A licensed surveyor is not mandatory for collection of as-built survey information. However, if a licensed surveyor is not being used, Contractor must demonstrate to Owner that their proposed method is suitably accurate to meet the needs of as-built information prior to start of construction.
18. Trees and other brush debris must be removed from the site, the landfill will charge the contractor for disposal of any materials except the existing 4" sludge line.
19. The contractor must furnish the pumps.
20. The owner will pay for all field tests, and lists required tests (02200-16).

### **Specifications**

- 00020 Invitation to bid**, Addition of substantial completion date. Base Contract, Alternative A and Alternative B modified to include sludge removal. New document attached.
- 00310 Bid Form**, Base Bid numbering error corrected, Item 6- Provide Sludge Removal, and Item 7 Mobilization/Demobilization added. New document attached.
- 00510 Agreement**, Substantial completion date added to agreement; the new document is attached.
- 01010 Summary of Work**, Base Contract, Alternative A and Alternative B modified to include sludge removal. New document attached.
- 01025 Measurement and Payment**, Removal of sludge hauling from unit price list of Bid Item 3, addition of Bid Item 6- Provide Sludge Removal, and Bid Item 7 Mobilization/Demobilization added. New document attached.

### **Drawings**

**2- General Notes:** Note 8.- typo corrected, Note 18.- deleted time constraint in section 1B limiting work to after September 1' Note 21.- Updated with new sludge quantities. New Note added: Note 22. States contractor to coordinate with City to flush the existing sludge line. Note 28 deleted- redundant to note 41, contractor to provide survey grade 3-d locates every 20' and at all significant features. Note 40 deleted, redundant to note 20 contractor responsible for fees and coordination of work in RR ROW with Rail Pros. Notes 40 to 42 added.

**13-Sludge Pump Notes and Details:** Corrected Note 7 for correct pump model NM105BY02S14V.2

### **ADDENDUM #1 ACKNOWLEDGED BY:**

Derck Duran  
Name

6-5-20  
Date

**PREPARED BY:**

**Chad Paulson, P.E., Alex Kordick, P.E.  
SGM**

---

***List of Attachments:***

*Specs 00020, 00310, 00510, 01010, 0125*

*Pre-bid sign in sheet*

*Drawings 2 and 13*





## ADDENDUM ORDER

ORDER NO. 4  
DATE: 6/8/2020  
BID DATE: 6/11/2020

NAME OF PROJECT: 2020 Sludge Handling Improvements – Phase 1

OWNER: City of Craig

ENGINEER: SGM

### The following changes are hereby made to the CONTRACT DOCUMENTS:

#### Clarifications

1. The carrier pipe must be seamless, Steel ASTM A53 grade B, minimum yield strength of 35,000psi, minimum 1/4" wall thickness. (Railroad dictated material, yield strength, and min. thickness). The RR does not designate any required coatings, please refer back to the City's Public works manual with requires protection from corrosion by the use of an approved bituminous coating.
2. The City has paid the UPRR permit costs, the contractor is only liable for the costs incurred from work with RailPros. The use of RailPros is a condition of the UPRR contract.
3. General Notes Sheet 2 Table 2-Craig Sludge Line Wetlands Seed Mix Clarifications:
  - a. Spearleaf Rabbit Brush wildland collected refers to plants not obtained from a national nursery catalogue, but instead locally sourced, or collected (collected from local rabbit brush seed).
  - b. Coyote Willow locally available stem cuts; "Stems refer to containerized willows or bare willow wands.

The following documents have been included to the contract documents to better define the project.

1. Specification 02224-Boring and Jacking


#### Specifications

**Specification 02224-Boring and Jacking**, new specification added to address casing pipe welding specifications.

#### Drawings

N/A

#### ADDENDUM #4 ACKNOWLEDGED BY:

  
Name

6-9-20  
Date

#### PREPARED BY:

Chad Paulson, P.E., Alex Kordick,

Currently there is no access from the top side of Loudy Simpson Park (through the Thompson Hill area) to the field where section 1B of the alignment is located. Contractors may access this area only from the below, through Loudy Simpson Park, a road along the pipe alignment during construction is acceptable.

Let me know if you have questions,

Thanks

Alex

**Alex Kordick, PE**

*Engineer III*



118 W Sixth St, Suite 200  
Glenwood Springs, CO 81601  
970.384.9065

[www.sgm-inc.com](http://www.sgm-inc.com)



RECEIVED & Acknowledged: Derek Duran

A handwritten signature in black ink, appearing to be "Derek Duran", written over the printed name.

6-9-20

The City will NOT provide or furnish any valves, tracer wire, wrap, etc. (Specs 01025-4 and 02667-3 incorrectly states owner will supply these). The contractor is responsible for all materials other than the culvert to places at the Southern edge of the WWTP property aligned with the permanent utility easement and new (contractor supplied double gate).

Thanks

Thanks

Alex

**Alex Kordick, PE**

*Engineer III*



118 W Sixth St, Suite 200  
Glenwood Springs, CO 81601  
970.384.9065

[www.sgm-inc.com](http://www.sgm-inc.com)



Received & Acknowledged: Derek Schen

A handwritten signature in black ink, appearing to be "Derek Schen", written over the printed name.

6-9-20

The full names and addresses of parties interested in this Bid as principals are as follows:

\_\_\_\_\_  
\_\_\_\_\_

SIGNATURE OF BIDDER:

Date: \_\_\_\_\_

If an Individual: \_\_\_\_\_, doing business as \_\_\_\_\_

If a Partnership: \_\_\_\_\_ by \_\_\_\_\_  
\_\_\_\_\_, partner

If a Corporation: \_\_\_\_\_ a \_\_\_\_\_ Corporation)  
by \_\_\_\_\_

(SEAL & TITLE \_\_\_\_\_, ATTEST)

Business Address of Bidder \_\_\_\_\_  
\_\_\_\_\_

If a Bidder is a joint venture, other party must sign below.

Date: \_\_\_\_\_

If an Individual: \_\_\_\_\_, doing business as \_\_\_\_\_

If a Partnership: by partner \_\_\_\_\_

If a Corporation: by \_\_\_\_\_

(SEAL & TITLE \_\_\_\_\_ ATTEST)

Business Address of Bidder \_\_\_\_\_

END OF SECTION

## SECTION 00510

### AGREEMENT

THIS AGREEMENT made this \_\_\_\_\_ day of \_\_\_\_\_ 2020 by and between the City of Craig and \_\_\_\_\_, hereinafter called the Contractor in the amount of \_\_\_\_\_, (\$ . ).

WITNESSETH that for and in consideration of the payments and agreements hereinafter mentioned:

1. The Contractor will commence and complete the construction of the City of Craig 2020 Sludge Handling Improvements-Phase 1, including all alternates awarded, no later than October 31, 2020. The contractor will achieve substantial completion no later than October 15, 2020. Failure to complete all construction within the contract time may result in assessment of Liquidated Damages that will accrue at the rate of \$700 per day.
2. The Contractor will furnish all labor, material, supplies, tools, equipment, utilities, transportation and other services necessary for the complete construction of the project described herein and in the related documents.
3. The Contractor will undertake the work required by the Contract Documents in not more than 30 days after the date of the Notice of Award and to complete said work within the period stated in the bid.
4. The Contractor agrees to perform all work described in the Contract Documents for the amounts itemized in the bid.
5. The term "Contract Documents" used herein means and includes the following.
  - A. Advertisements for Bids
  - B. Information for Bidders
  - C. Bid
  - D. Data Sheets if requested
  - E. List of Subcontractors
  - F. Statement of Qualifications
  - G. Bid Bond
  - H. Contract
  - I. Performance Bond
  - J. Payment Bond
  - K. General Conditions
  - L. Special Provisions
  - M. Construction Specifications



N. Plans  
O. Addenda

IN WITNESS WHEREOF, the parties hereto have executed, or caused to be executed by their duly authorized officials, this agreement on the date last written above.

Owner:

\_\_\_\_\_

Name: \_\_\_\_\_

By: \_\_\_\_\_

SEAL  
ATTEST:

\_\_\_\_\_

Name: \_\_\_\_\_

Title: \_\_\_\_\_

Contractor:

\_\_\_\_\_

Name: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Address: \_\_\_\_\_

SEAL  
ATTEST:

\_\_\_\_\_

Name: \_\_\_\_\_

Title: \_\_\_\_\_

END OF SECTION

## SECTION 00510

### AGREEMENT

THIS AGREEMENT made this \_\_\_\_\_ day of \_\_\_\_\_ 2020 by and between the City of Craig and \_\_\_\_\_, hereinafter called the Contractor in the amount of \_\_\_\_\_, (\$ . ).

WITNESSETH that for and in consideration of the payments and agreements hereinafter mentioned:

1. The Contractor will commence and complete the construction of the City of Craig 2020 Sludge Handling Improvements-Phase 1, including all alternates awarded, no later than October 31, 2020. The contractor will achieve substantial completion no later than October 15, 2020. Failure to complete all construction within the contract time may result in assessment of Liquidated Damages that will accrue at the rate of \$700 per day.
2. The Contractor will furnish all labor, material, supplies, tools, equipment, utilities, transportation and other services necessary for the complete construction of the project described herein and in the related documents.
3. The Contractor will undertake the work required by the Contract Documents in not more than 30 days after the date of the Notice of Award and to complete said work within the period stated in the bid.
4. The Contractor agrees to perform all work described in the Contract Documents for the amounts itemized in the bid.
5. The term "Contract Documents" used herein means and includes the following.
  - A. Advertisements for Bids
  - B. Information for Bidders
  - C. Bid
  - D. Data Sheets if requested
  - E. List of Subcontractors
  - F. Statement of Qualifications
  - G. Bid Bond
  - H. Contract
  - I. Performance Bond
  - J. Payment Bond
  - K. General Conditions
  - L. Special Provisions
  - M. Construction Specifications

N. Plans  
O. Addenda

IN WITNESS WHEREOF, the parties hereto have executed, or caused to be executed by their duly authorized officials, this agreement on the date last written above.

Owner:

\_\_\_\_\_

Name: \_\_\_\_\_

By: \_\_\_\_\_

SEAL  
ATTEST:

\_\_\_\_\_

Name: \_\_\_\_\_

Title: \_\_\_\_\_

Contractor:

\_\_\_\_\_

Name: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Address: \_\_\_\_\_

SEAL  
ATTEST:

\_\_\_\_\_

Name: \_\_\_\_\_

Title: \_\_\_\_\_

END OF SECTION

SECTION 00410

BID SECURITY

2020 Sludge Handling Improvements - Phase 1  
CITY OF CRAIG

THE STATE OF Colorado )  
COUNTY OF Moffat ) KNOW ALL MEN BY THESE PRESENTS

That, we, Duran & Pearce Contractors, Inc of the City of Craig,  
County of Moffat and State of Colorado (hereinafter called  
Bidder) as principal, and National American Insurance Company (hereinafter call  
Surety) as surety, authorized under the laws of the State of Colorado to act as surety on bonds  
for bidders, are held and firmly bound unto the City of Craig (hereinafter called Owner) as  
obliged, in the penal sum of thirty nine thousand five hundred  
(\$ 39,500.00 ) Dollars in lawful money of the United States for  
payment of Bidders and Surety, bind themselves, their heirs, executors, administrators, successors  
and assigns, jointly and severally and firmly by these presents.

WHEREAS, Bidder has submitted a Bid to enter into a certain written contract with Owner for  
Construction of Phase 1 of the 2020 Sludge Line Improvements here in after referred to as  
Contract

NOW, THEREFORE, the condition of this obligation is such that if Owner shall accept the Bid of  
the Bidder and Bidder shall faithfully enter into a contract with the Owner in accordance with the  
terms of such Bid and give such Bonds as are specified in the Bidding or Contract Documents; or  
in the event of the failure of Bidder to enter such Contract and give such bond or bonds, if Bidder  
shall pay to Owner the difference not to exceed the penalty hereof between the amount specified  
in said Bid and such larger amount for which Owner may in good faith contract with another  
party to perform the Work covered by said Bid, then this obligation shall be null and void,  
otherwise to remain in full force and effect.

Signed and sealed this 11th day of June, 2020

Bidder as Principal

Duran & Pearce Contractors, Inc.

By



Derek Duran, Vice President


PO Box 1331, Craig, CO 81626

Address

Surety

National American Insurance Company

By



M. Shane Camilletti, Attorney-In-Fact

100 E Victory Way, Craig, CO 81625

Address

Surety's Telephone No.

405-258-0804

END OF SECTION



**NATIONAL AMERICAN INSURANCE COMPANY  
CHANDLER, OKLAHOMA  
POWER OF ATTORNEY**

Number: CBB0053835

**DUPLICATES SHALL HAVE THE SAME FORCE AND EFFECT AS AN ORIGINAL ONLY WHEN ISSUED IN CONJUNCTION WITH THE ORIGINAL.**

KNOW ALL MEN BY THESE PRESENTS: That the National American Insurance Company, a corporation duly organized under the laws of the State of Oklahoma, having its principal office in the city of Chandler, Oklahoma, pursuant to the following resolution, adopted by the Board of Directors of the said Company on the 8th day of July, 1987, to wit:

"Resolved, that any officer of the Company shall have authority to make, execute and deliver a Power of Attorney constituting as Attorney-in-fact, such persons, firms, or corporations as may be selected from time to time.

Resolved that nothing in this Power of Attorney shall be construed as a grant of authority to the attorney(s)-in fact to sign, execute, acknowledge, deliver or otherwise issue a policy or policies of insurance on behalf of National American Insurance Company.

Be It Further Resolved, that the signature of any officer and the Seal of the Company may be affixed to any such Power of Attorney or any certificate relating thereto by facsimile, and any such Power of Attorney or certificate bearing such facsimile signature or facsimile seal shall be valid and binding upon the Company and any such powers so executed and certified by facsimile signature and facsimile seal shall be valid and binding upon the Company in the future with respect to any bond and documents relating to such bonds to which it is attached."

National American Insurance Company does hereby make, constitute and appoint

**M. Shane Camilletti; Lance Hackworth; Joe Nieslanik; Ashley Demos; Scott Mayor; Jarad Lyons; Onita DeJulio;  
Alisa Corey; Bentley Colbert**

its true and lawful attorney(s)-in-fact, with full power and authority hereby conferred in its name, places and stead, to sign, execute, acknowledge and deliver in its behalf, and its act and deed, as follows:

To bind the company for bonds, not to exceed \$4,000,000.00 for any single bond. And to bind National American Insurance Company thereby as fully and to the same extent as if such bonds and documents relating to such bonds were, signed by the duly authorized officer of the National American Insurance Company, and all the acts of said Attorney(s) pursuant to the authority herein given, are hereby ratified and confirmed.

IN WITNESS WHEREOF, the National American Insurance Company has caused these presents to be signed by any officer of the Company and its Corporate Seal to be hereto affixed.



NATIONAL AMERICAN INSURANCE COMPANY

*W. Brent LaGere*

W. Brent LaGere, Chairman & Chief Executive Officer

STATE OF OKLAHOMA     )  
COUNTY OF LINCOLN    )   SS:

On this 26<sup>th</sup> day of September, A.D. 2017, before me personally came W. Brent LaGere, to me known, who being by me duly sworn, did depose and say; that he resides in the County of Lincoln, State of Oklahoma; that he is the Chairman and Chief Executive Officer of the National American Insurance Company, the corporation described in and which executed the above instrument; that he knows the seal of said corporation; that the seal affixed to the said instrument is such corporate seal; that it was so affixed by order of the Board of Directors of said corporation and that he signed his name, thereto by like order.



*Janet Taylor*

Notary Public  
My Commission Expires April 8, 2022  
Commission #02006203

STATE OF OKLAHOMA     )  
COUNTY OF LINCOLN    )   SS:

I, the undersigned, Secretary of the National American Insurance Company, an Oklahoma Corporation, DO HEREBY CERTIFY that the foregoing and attached POWER OF ATTORNEY remains in full force.

Signed and Sealed at the City of Chandler.

Dated the 9<sup>th</sup> day of June, 2020



*R. Patrick Gilmore*

R. Patrick Gilmore, Secretary



## *"HELD TO A HIGHER STANDARD"*

June 11th, 2020

Jarrold Ogden – Mayor  
Trevor Campbell & Shane Baker  
City of Craig  
300 W. 4<sup>th</sup> St  
Craig, Co 81625

### **RE: 2020 SLUDGE HANDLING IMPROVEMENTS**

To Whom It May Concern:

Thank you for giving Duran & Pearce Contractors, Inc the opportunity to submit a proposal for the City of Craig 2020 Sludge Handling Improvements. This proposal is based on the information from the mandatory bid walk that Duran & Pearce Contractors attended as well as the Specifications and Contract Documents that were provided by the City of Craig and SGM. Duran & Pearce Contractors is aware of the tight construction schedule as well as the Liquidated Damages. If successful, Duran & Pearce will provide Construction Schedules and Phases with 10 days. If requested, Duran & Pearce can provide project past experience and references if necessary. Duran & Pearce Contractors is fully bonded and insured. Please find the following in this Bid Packet:

- D&P Line Item Bid Schedule
- Addendum No: 1-4 Signature
- Subcontractor List
- Past Project Experience
- Experience Modification Rate
- Surety Reference / Payment & Performance Bond – (Cost of Bond Included in Unit Costs)

We look forward in working with the City of Craig

Thank you,

A handwritten signature in black ink, appearing to read 'Derek Duran', with a long horizontal flourish extending to the right.

*Derek Duran*  
Owner

[Derek.dpcontractors@gmail.com](mailto:Derek.dpcontractors@gmail.com)  
970.629.8360 Cell  
970.824.4014 Office



*"HELD TO A HIGHER STANDARD"*

## **Scope of Work**

### **PHASE 1:**

- Furnish and Install 2,730 LF of 6" DR9 HDPE Pipe
  - o Excavate, bed and compact new pipe
  - o Seeding / Erosion Control
  - o De-watering
  - o Provide survey as-builts
- Furnish and Install New Sludge Pumps
- Demo and Remove electrical to pumps, existing pumps and misc. piping
- Bore Under Yampa River and UPRR ROW
  - o Pricing for installation as per the provided geotechnical investigation. If boring refusal, substantial cobble or gravels are encountered, casing and or pipe ramming equipment maybe required at additional cost. Additional costs to occur if material is other than that identified through the soil investigation
  - o Proposal does not include solid rock (mud motor) drilling
- Proposal includes price of UPRR Construction Observation Fees and Flaggers
- Provide Sludge Removal throughout duration of Phase 1
- Tie new 6" HDPE into existing 4" Sludge Line
- Initial Survey by owner
- All Compaction testing by Owner

*Proposal is based off of all construction documents provided. Change in scope of work will result in change of project cost. Costs to be discussed and agreed upon prior to work continuing. If contractor is delayed due to unforeseen circumstances, then additional working days to be added to schedule.*





## *"HELD TO A HIGHER STANDARD"*

### **PHASE 1 A:**

- Install approx. 950 LF of 6" DR9 HDPE Pipe
  - o Excavate, bed and compact new pipe
  - o Seeding / Erosion Control
  - o De-watering
  - o Provide survey as-builts
- Provide Sludge Removal throughout duration of Phase 1A
- Tie new 6" HDPE into existing 4" Sludge Line
- Initial Survey by owner
- All Compaction testing by Owner
- Provide construction fencing / barricades in open park area
- Assume portion of Loudy Simpson Park can be closed to the public throughout duration of 1A

### **PHASE 1B:**

- Install approx. 1,500 LF of 6" DR9 HDPE Pipe
  - o Excavate, bed and compact new pipe
  - o Seeding / Erosion Control
  - o De-watering
  - o Provide survey as-builts
- Provide Sludge Removal throughout duration of Phase 1A
- Tie new 6" HDPE into existing 4" Sludge Line
- Initial Survey by owner
- All Compaction testing by Owner
- Disc existing wheat field – No Seeding
  
- *Proposal is based off of all construction documents provided. Change in scope of work will result in change of project cost. Costs to be discussed and agreed upon prior to work continuing. If contractor is delayed due to unforeseen circumstances, then additional working days to be added to schedule.*



*"HELD TO A HIGHER STANDARD"*

**LIST of QUALIFIED SUBCONTRACTORS**

**SUBCONTRACTORS TO BE USED ON PROJECT**

***DUCEY ELECTRIC***

***ELITE DRILLING COMPANY***

***MADSEN FABRICATION***

***FORBES WELDING SERVICES***

***ACTION SERVICES***



*"HELD TO A HIGHER STANDARD"*

## **Past Project Experience**

### **30" Raw Water Line Install**

- Tri- State G&T, Craig, Co
- Excavate for 5,000 LF of 30" Steel Pipe / Backfill and Compact
- Project consisted of excavating near pressurized 'live' 30" water line

### **MRH Mob Expansion Project:**

- Projected consisted of install of 30,000 CY of fill material
- Install 3,000 LF of Underground Utilities
- 8" Water Main, 8" Sewer Main and 24" Storm water Line

### **City of Craig 8" Water Valve Tie-ins**

- Project consisted of excavating and removal of (4) 8" Gate Valves at the intersection of Victory Way and Yampa Ave. Install new gate vales on 4-way tee. Backfill compact

### **Misc. City of Craig Water Main Repairs**

- Excavate and repair City of Craig Water Main Infostructure