

Monthly Report

Wastewater

April 2021

A. Treatment – Operation:

1. Operated treatment plant to comply with State and Federal regulations.
2. Performed daily, weekly, and monthly maintenance as recommended in the manufacturer's manuals.
3. Treated average of 864,000 gallons/day of wastewater.
4. Received and treated 1,800 gallons of hauled waste.

B. Collection – Operation:

1. 136 man hours used to perform 181 line locates.
2. 32 man hours used to hydraulically clean 0.75 miles of sewer main as part of routine (every 5 weeks) maintenance.
3. 15 man hours used to hydraulically clean 0.96 miles of sewer main as part of an annual cleaning program.

c. Collection – Correction

1. 2 man hours used to respond to a complaint of sewage coming up through road at 2035 Crockett Dr. The main was inspected and found to be flowing well. Video inspection of the main showed no defects. It was determined to be a broken service line. Homeowner was advised.
2. 3 man hours used to respond to a backup complaint at 1130 Legion St. Homeowner reported sewage coming in through floor drain. The main was inspected and roots were found to be causing the backup. Once the roots were removed, flow was restored. Homeowner stated that no damage occurred to his home. This site has been added to the routine cleaning and herbicide application lists to help prevent further issues.

D. Other:

1. Assisted other departments, local plumbers, and contractors as needed.
2. Analyzed Maybell's Wastewater Plant monthly samples.
3. Safety meeting attended by all Wastewater personnel.