

Craig’s 2022 Drinking Water Quality Report

Covering Data For Calendar Year 2021

Esta es información importante.
Si no la pueden leer, necesitan
que alguien se la traduzca.

The City of Craig is pleased to present this year’s water quality report. Our constant goal is to provide you with a safe and dependable supply of drinking water. Craig’s Water Treatment Plant (PWSID# CO 0141188) produced almost 615 million gallons of drinking water in 2021. Operators at the water plant perform thousands of tests each year to ensure that our drinking water is free of physical, chemical, and biological contaminants. Please take a few minutes to read through this material and, if you have questions, or for participation opportunities that may affect water quality, please contact Mark Sollenberger, the Water and Wastewater Director, at 970-824-6340. Also, you’re welcome to voice opinions at the city council meetings held on the 2nd and 4th Tuesday of the month at 6:30 P.M. at City Hall. Of course, you are always welcome to call the water plant to get answers to any questions you may have, or to request a tour of the treatment plant.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of the contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline (1-800-426-4791) or by visiting epa.gov/ground-water-and-drinking-water.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and microbiological contaminants call the EPA Safe Drinking Water Hotline at (1-800-426-4791).

Craig’s drinking water source is surface water that comes from the Yampa River intake. There are 27 rivers and streams that comprise the Yampa River watershed above Craig. In the event of a severe drought, the Elkhead Reservoir can be used to supplement our water source supply. The sources of drinking water (both tap water and bottled water) include river, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- **Microbial contaminants**, viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides** may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.
- **Radioactive contaminants**, can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Source Water Assessment & Protection (SWAP)

The Colorado Department of Public Health and Environment has provided us with a Source Water Assessment Report for our water supply. For general information or to obtain a copy of the report please visit wqcdcompliance.com/ccr, the report is located under “Guidance: Source Water Assessment Reports”, and then search the table using (141188; Craig City of) or by contacting Mark Sollenberger at 970-824-6340.

The Source Water Assessment Report provides a screening-level evaluation of potential contamination that **could** occur. It does not mean that the contamination **has or will** occur. We can use this information to evaluate the need to improve our current water treatment capabilities and prepare for future contamination threats. This can help us ensure that quality finished water is delivered to your homes. In addition, the source water assessment results provide a starting point for developing a source water protection plan. Please contact Mark Sollenberger at 970-824-6340 to learn more about what you can do to help protect your drinking water sources, any questions about the Drinking Water Consumer Confidence Report, to learn more about our system, or to attend scheduled public meetings. We want our valued customers to be informed about the services we provide, and the quality water we deliver to you every day. Potential sources of contamination in our source water are listed on the next page.

Terms and Abbreviations

It is important to understand some terms that we use frequently at the water plant. Following are several of these terms and their definitions. Take a moment to read these terms so you are better able to understand the information in the succeeding tables.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment and other regulatory requirements.

Average (x-bar): Typical value. Mathematically it is the sum of values divided by the number of samples.

Compliance Value (No Abbreviation): Single or calculated value used to determine if regulatory contaminant level (e.g. MCL) is met. Examples of calculated values are the 90th Percentile, Running Annual Average (RAA), and Locational Running Annual Average (LRAA)

Formal Enforcement Action (No Abbreviation): Escalated action taken by the State (due to the risk to public health, or number or severity of violations) to bring a non-compliant water system back into compliance.

Below Detectable Limit (BDL): Indicates that a contaminant was undetectable during the testing procedure.

Gross Alpha (No Abbreviation): Gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222 and uranium.

Health Based: A violation of either a MCL or TT.

Level 1 Assessment: A study of the water system to identify potential problems, and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A very detailed study of the water system to identify potential problems, and determine (if possible) why an E. coli MCL violation has occurred, and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water, below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Non-Health Based: A violation that is not a MCL or TT.

Not Applicable (N/A): Does not apply or is not available.

Nephelometric Turbidity Unit (NTU): Measure of the clarity or cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the typical person.

Parts Per Million = Milligrams per Liter (ppm = mg/L): One part per million corresponds to one minute in two years, or a single penny in \$10,000.

Parts Per Billion = Micrograms per Liter (ppb = ug/L): One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries/Liter (pCi/L): Measure of radioactivity in water.

PWSID: Public Water System Identification Number.

Running Annual Average (RAA): Average of quarterly averages. Calculated from four of “most recent quarters”.

Range (R): Lowest value to the highest value.

Sample Size (n): Number or count of values (i.e. number of water samples collected).

Total Organic Carbon (TOC): A measure of the total amount of carbon in water, present as organic molecules.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Variance and Exemptions (V/E): Department permission not to meet a MCL or a treatment technique under certain conditions.

Violation (No Abbreviation): Failure to meet a Colorado Primary Drinking Water Regulation.

Waiver: State permission not to test for a contaminant. Our plant has a waiver for: Dioxin, Glyphosphate, Nitrite, Cyanide, and Asbestos.

Detected Contaminants

The City of Craig routinely monitors for contaminants in your drinking water according to Federal and State laws. The following tables show all detections found in the period of January 1 to December 31, 2021 unless otherwise noted. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one year old. Violations and Formal Enforcement Actions, if any, are reported in the final section of this report.

Note: Only detected contaminants sampled within the last 5 years appear in this report. If no tables appear in this section, then no contaminants were detected in the last round of monitoring.

Our Water Sources

<u>Sources (Water Type – Source Type)</u>	<u>Potential Source(s) of Contamination</u>
Yampa River (Surface Water -Intake)	EPA Hazardous Waste Generators, EPA Chemical Inventory/Storage Sites, EPA Toxic Release Inventory Sites, Permitted Wastewater Discharge Sites, Aboveground, Underground and Leaking Storage Tank Sites, Solid Waste Sites, Existing/Abandoned Mine Sites, Other Facilities, Commercial/Industrial/Transportation, High Intensity Residential, Low Intensity Residential, Urban Recreational Grasses, Row Crops, Pasture/Hay, Deciduous Forest, Evergreen Forest, Mixed Forest, Septic Systems, Oil/Gas Wells, Road Miles.

Lead and Copper in your drinking water

Starting in 2018 we test 40 sites twice annually throughout the city for Lead and Copper levels in the drinking water. Homes are selected that are likely to show high levels of these elements, if present in the drinking water. To be in compliance, 90% of these homes must have Lead and Copper Action Levels below 15 ppb and 1300 ppb respectively. If present, elevated levels of lead can cause serious health problems, (especially for pregnant women and young children). Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Craig Water Plant is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. It is possible that lead levels at your home may be higher than other homes in the community as a result of materials used in your home’s plumbing. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Additional information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at (1-800-426-4791) or at [epa.gov/safewater/lead](https://www.epa.gov/safewater/lead).

Contaminant Name	Time Period	90 th Percentile Result	Unit	Action Level	Sample Size
Copper	4-09 to 5-20-2021	0.18	ppm	1.3 ppm	40
Lead	4-09 to 5-20-2021	1.0	ppb	15.0 ppb	40
Copper	9-25 to 10-12-2021	0.19	ppm	1.3 ppm	40
Lead	9-25 to 10-12-2021	1.7	ppb	15.0 ppb	40

We tested 40 sites for Lead and Copper twice (April & September) in 2021 and the maximum 90th percentile level for Lead was 1.7 ppb, and for Copper it was 0.19 ppm, both well below the Action Level established by the EPA. None of the sites exceeded the Action Level for Lead or Copper. Typical sources of lead and copper are corrosion of household plumbing or erosion of natural deposits. We will again retest for Lead and Copper twice in 2022.

The Craig Water Plant tests for SOC's every three years. We sample for VOC's annually.

For the most part, the following chemicals enter the source water via storm and/or spring runoff, residential, industrial, and agricultural uses.

Synthetic Organic Chemicals (SOC's) - Regulated
SOC's are man-made compounds used in industrial applications. They include: solvents, paints, plastics, dyes, and food additives.

Volatile Organic Chemicals (VOC's) - Regulated
The sources of these chemicals include: pesticides, herbicides, and industrial solvents. A number of these are suspected carcinogens. State certified labs **tested twice for SOC's** at our water plant in 2021. **None** of these regulated contaminants were **detected** in our drinking water. We tested for VOC's in 2021 and **none** were found. We will sample for SOC's again in 2024. A complete list of these chemicals and the results are available at the water plant.

We check for these chemicals annually. We submitted samples for these contaminants on 04/13/2021

Inorganic Chemicals - Regulated
These are metals and salts, which can be naturally occurring or can result from urban storm water runoff, industrial discharges, oil and gas production, mining, and farming. The **following chemicals were below the detectable limit** in your drinking water in the 2021 analysis: Arsenic, Beryllium, Cadmium, Chromium, Mercury, Nickel, Nitrate, and Thallium.

The following chemicals were found at the stated level in the sample date indicated: **(Sample Date)**

Antimony was detected at a level of 0.89 ppb	(MCL is 6.0 ppb)	(MCLG is 6.0 ppb)	(04-13-2021)
Discharge from petroleum refineries, fire retardants, ceramics, electronics, and solder			
Barium was detected at a level of 0.019 ppm	(MCL is 2.0 ppm)	(MCLG is 2.0 ppm)	(04-13-2021)
Drinking water containing barium in excess of the MCL over many years may increase blood pressure.			
Fluoride was detected at a level of 0.67 ppm	(MCL is 4.0 ppm)	(MCLG is 4.0 ppm)	(04-13-2021)
Fluoride in drinking water at lower levels has been proven to help promote stronger teeth. The Colorado Department of Public Health and Environment - Oral Health Division recommends a fluoride level of (0.6 to 0.9 ppm) be maintained in public drinking water systems that fluoridate their water.			
Selenium was detected at a level of 1.1 ppb	(MCL is 50.0 ppb)	(MCLG is 50.0 ppb)	(04-13-2021)
Discharges from petroleum or metal refineries, erosion of natural deposits, and discharges from mines.			

Summary of Turbidity Sampled at the Entry Point to the Distribution System					
Contaminant Name	Sample Date	Level Found	TT Requirement	TT Violation	Typical Sources
Turbidity	Month/August	<u>Highest single</u> measurement 0.295 NTU	Maximum 1.0 NTU for any single measurement	NO	Soil Runoff
Turbidity	Month: December	Lowest monthly percentage of samples meeting TT requirement for our technology: 100%	In any month, at least 95% of samples must be less than 0.3 NTU	NO	Soil Runoff

In July of 2000, the Craig Water Plant became certified to perform Total Coliform tests. We renewed this certification in 2021. This allows us to obtain a faster turnaround time on our samples, and to perform additional testing when needed. We test 10 different sites every month throughout the city for bacteria (P&A) method for Total Coliform & E-Coli bacteria.

Micro-organisms - Bacteria and parasites in the water can cause severe illness and even death. For this reason, we closely monitor for these organisms. The combination of treatment process, filtration in particular, and disinfection with chlorine, helps to ensure that your drinking water is free of these biological entities. Sources of these contaminants include: sewage treatment plants, septic systems, livestock operations, and wildlife.

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found **no** coliform bacteria in 2021.

<u>Test</u>	<u>MCL</u>	<u>Result</u>
Total Coliforms	≤1 “present” sample/ month	None Detected

We collect samples for the following analysis quarterly.

Total Trihalomethanes (TTHMs) Haloacetic Acids (HAAs) - Regulated VOCs

These may be formed as a byproduct of drinking water disinfection when chlorination reacts with natural organic material in the water. Some THMs are thought to be cancer causing agents at certain levels. TTHMs are the sum of: bromodichloromethane, dibromochloromethane, bromoform, and chloroform. HAAs we test for include: Mono, di, and trichloroacetic acid, mono and dibromoacetic acid. Regulatory compliance is based off of the RAA of four consecutive quarters.

<u>Test</u>	<u>Unit</u>	<u>MCL</u>	<u>Average</u>	<u>Range</u>	<u>Sample Size</u>
TTHMs	ppb	80 ppb	RAA = 53.18 ppb	43.5 – 67.6 ppb	8
HAAs	ppb	60 ppb	RAA = 38.21 ppb	30.0 – 48.8 ppb	8

Some people who drink water containing THMs and HAAs in excess of the MCL over many years may have an increased risk of getting cancer.

We test for Total Organic Carbon (TOC) once every month. TOC is naturally present in the environment. Compliance is based on percent removal ratio between the source water TOC, and the finished water TOC.

<u>Test</u>	<u>Unit</u>	<u>MCL</u>	<u>Average of Individual Ratio Samples</u>	<u>Range</u>	<u>Samples Size</u>
TOC	Removal Ratio	< 1.0 (TT)	RAA 1.41	1.01 - 2.3	12

TOC has no health effects. We use enhanced treatment to remove the required amount of natural organic material and/or we demonstrated compliance with alternative criteria. However, these chemicals provide a medium for the formation of disinfection byproducts, which include Trihalomethanes (THMs) and Haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, nervous system effects, or increased risk of getting cancer. * If the minimum ratio is not met and no violation identified, then the system achieved compliance using alternative criteria.

Disinfectants Sampled in the Distribution System

TT Requirement: At least 95% of samples per period (month or quarter) must be at least 0.2 ppm **OR**
If sample size is less than 40 no more than (1) sample is below 0.2 ppm.

Typical Sources: Water additive used to control microbes.

<u>Disinfectant Name</u>	<u>Time Period</u>	<u>Results</u>	<u>Number of Samples Below Level</u>	<u>Sample size</u>	<u>TT Violation</u>	<u>MRDL</u>
Chloramine	December, 2021	<u>Lowest period</u> percentage of samples meeting TT requirement: 100%	0	10	No	4.0 ppm

We tested for Alpha Emitters, Beta Emitters, Radium 228, Radium 226 and Uranium in 2013. We will test again in 2022.

Radioactive Contaminants

Sources of Radioactive contaminants include nature, nuclear power plants, processing plants, and uranium mines. These contaminants have been proven to cause cancer. The following levels were detected in the most recent sample:

Gross Alpha Emitters (Natural Radioactivity):	Average 1.3 pCi/L (MCL is 15 pCi/L)	Range 1.3 - 1.3 pCi/L (MCLG is 0 pCi/L)
Radium 228/226 Combined (Natural Radioactivity):	Average 0.6 pCi/L (MCL is 5 pCi/L)	Range 0.6 - 0.6 pCi/L (MCLG is 0 pCi/L)

Drinking water containing Radium 228/226 in excess of MCL over many years may result in an increased risk of cancer.

The Water Plant tests for other minerals and characteristics of your drinking water, such as: pH, alkalinity, hardness, conductivity, TDS, iron, and salinity. Results for these tests are available at the water plant.

<u>Secondary Contaminants/ Other Monitoring</u>	<u>Sample Date</u>	<u>Peak Value</u>	<u>Average</u>	<u>Range</u>	<u>Unit</u>	<u>Secondary Standard</u>
Total Dissolved Solids	10/19/2021	200.0	200.0	200 – 200	ppm	500
Sodium	04/13/2021	30.9	30.9	30.9 – 30.9	ppm	N/A

Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water.

Unregulated Contaminants***

EPA has implemented the Unregulated Contaminant Monitoring Rule (UCMR) to collect data for contaminants that are suspected to be present in drinking water and do not have health-based standards set under the Safe Drinking Water Act. EPA uses results of the UCMR monitoring to learn about occurrence of unregulated contaminants in the drinking water and decide whether or not these contaminants will be regulated in the future. We performed monitoring, and reported the analytical results of the monitoring to EPA in accordance with its Unregulated Contaminants Monitoring Rule (UCMR). Once EPA reviews the submitted results, the results are made available in the EPA’s National Contaminant Occurrence Database (NCOD) at (epa.gov/dwucmr/national-contaminant-occurrence-database-ncod). Consumers can review UCMR results by accessing the NCOD. **There were no contaminants detected (BDL) during our UCMR sampling.**

*****More information about contaminants that were included in the UCMR monitoring can be found at:**

(drinktapp.org/Water-Info/Whats-In-My-Water/Unregulated-Contaminant-Monitoring-Rule-UCMR). Learn more about the EPA UCMR at: (epa.gov/dwucmr/learn-about-unregulated-contaminant-monitoring-rule), or contact the Safe Drinking Water Hotline at 1-800-426-4791 or (epa.gov/ground-water-and-drinking-water).

Violations, Significant Deficiencies, or Formal Enforcement Actions

“No Violations or Formal Enforcement Actions”

A copy of this report is available to all interested parties and can be picked up at the water plant and at City Hall or visit our web site at www.ci.craig.co.us. Always feel free to call us at 824-6340 with questions and/or comments. State and federal drinking water regulations are ever-changing, and the operators at the Craig Water Plant are alert to these changes. We are watchful for new technologies that will improve the quality of your drinking water and enable us to meet or exceed the drinking water quality standards.