



CITY OF ELMHURST

209 NORTH YORK STREET
ELMHURST, ILLINOIS 60126-2759
(630) 530-3000
www.elmhurst.org

STEVEN M. MORLEY
MAYOR
PATTY SPENCER
CITY CLERK
ELAINE LIBOVICZ
CITY TREASURER
JAMES A. GRABOWSKI
CITY MANAGER
JEFFERY W. BACIDORE
FIRE CHIEF

By Order of the Fire Chief of the City of Elmhurst (Authority of the adopted Fire Code Section 102.9)

Plumbing Work Effective Oct. 16, 2015

Purpose of the Rule:

The purpose of this rule is for the protection of life and property in the City of Elmhurst.

Scope of the Rule:

This rule shall apply to all plumbers performing work in the City of Elmhurst.

Plumbing Work Rule:

On every jobsite all licensed plumbers performing work in the City of Elmhurst shall have a readily accessible Fire Extinguisher on each level that work is being performed. The Fire Extinguisher shall be a multi-purpose dry chemical extinguisher that is UL rated for ABC use. The minimum size shall be a 2 ½ lb. extinguisher and a have a rating of 1A 10BC.

Failure to Comply:

Whenever a City of Elmhurst Code Official finds work being performed in a manner contrary to this rule, the Code Official is authorized to issue a stop work order. A stop work order shall be in writing and shall be given to the owner of the property, or to the owner's agent, or to the person doing the work. Upon issuance of a stop work order, the cited work shall immediately cease. The stop work order shall state the reason for the order, and the conditions under which cited work is authorized to resume.