

HOOKSETT FIRE RESCUE DEPARTMENT

15 LEGENDS DRIVE - HOOKSETT, NEW HAMPSHIRE 03106

PHONE: (603) 623-7272

FAX: (603) 626-6742



GRAPHIC MAP GUIDELINES

1. Graphic Maps are required in all new systems. A graphic annunciator may be used in lieu of a map in special circumstances with AHJ approval.
2. The building graphic(s) shall be oriented in respect of the viewer when the annunciator is in its installed location(s).
3. “You are here” text and arrow shall be provided in red.
4. Floor outlines shall be “triple thick” solid black. Interior partitions shall be “double thick” solid black. Areas with building above or below, or not accessible at the identified level shall be depicted with a broken “double thick” line. Other lines of lesser significance shall be “single thick”.
5. All shafts shall be depicted with crossed lines from corner to corner.
6. Graphics having significant detail shall have stairways shaded in blue and elevators yellow. Stairways shall be labeled identically to stairwell signage package (i.e., west stair, main stair, etc.).
7. Points of egress/ingress shall be clearly indicated.
8. Either breaking the wall line or showing the door swing shall identify all interior doors.
9. Smoke and fire separation lines shall be indicated via zone annunciation and a red dashed line.
10. Roof access point(s) shall be identified.
11. Electrical, mechanical, fire pump and fire alarm rooms shall be identified.
12. All fire alarms, sprinkler, standpipe and other fire control devices shall be shown with red symbols and identification (i.e., FDV’s, FDC’s, Automatic Sprinkler valves, Riser Valves, etc.).
13. All AHU’s, elevator associated initiating devices, and other point specific initiating devices shall be identified and annunciated via a “hot point”. All other annunciation shall be via back lighting.
14. Openings in floors such as atriums, light wells, and the like shall state “open to below”.
15. Smoke exhaust fan locations shall be identified. (SEF #... is an acceptable abbreviation).

16. Major building spaces shall be identified. Examples would include mezzanine (north, west, main, center etc.) mechanical rooms, fire pump room, and electrical rooms.