



Drinking Water Results

A year of quarterly samples are required to establish official levels,

| Drinking Water Results | | | | Treatment Plant 1 | Treatment Plant 1 | Treatment Plant 1 | Treatment Plant 2 ¹ | Treatment Plant 2 ¹ |
|------------------------|--------------|--------------------|-------------------|--------------------|--------------------|---------------------|--------------------------------|--------------------------------|
| Chemical | EPA Advisory | Proposed EPA Limit | CA Response Level | Test Date 2/7/2023 | Test Date 5/3/2023 | Test Date 11/7/2023 | Test Date 5/3/2023 | Test Date 8/7/2023 |
| PFOA | 4.0 | 4.0 | 10.0 | 9.6 | 8.7 | 9.8 | 12.0 | 14.0 |
| PFOS | 20.0 | 4.0 | 40.0 | 4.5 | 4.6 | 4.8 | 5.9 | 7.2 |
| PFHpA | TBD | TBD | TBD | 4.1 | 3.8 | 4.7 | 5.6 | 5.7 |
| PFHxA | TBD | TBD | TBD | 4.7 | 4.6 | 5.4 | 6.6 | 6.7 |
| PFPeA | TBD | TBD | TBD | 3.5 | 3.7 | 3.6 | 3.9 | 4.5 |
| PFDA | TBD | TBD | TBD | ND | ND | ND | 3.0 | 3.9 |
| PFHxS | TBD | TBD | TBD | ND | ND | ND | ND | 3.3 |
| PFNA | TBD | TBD | TBD | ND | ND | ND | ND | 4.6 |

¹This treatment plant is currently offline
 ND = Non Detect, TBD = To Be Determined
 All results are parts per trillion