# decks.com

# **Deck Construction Guide**

Typical Deck Construction Detail	Sheet 1
Frost Footing Detail	Sheet 2
Typical Deck Ledger Board Details	Sheet 3
Typical Deck Ledger Board Details 2	Sheet 4
Lateral Support Of Free Standing Deck	Sheet 5
Deck Beam and Joist Details	Sheet 6
Post and Beam Detail	Sheet 7
Typical Stair Detail	Sheet 8
Typical Stair Attachment Detail	Sheet 9
Typical Guard Rail Detail	heet 10

Based on the 2006 International Residential Code

# **Typical Deck Construction Detail**



#### **DESIGN LOADS**

All decks shall be designed to support a live load of 40 lbs. per square foot and a dead load of 15 lbs. per square foot.

#### WOOD REQUIREMENTS

Unless noted otherwise in these details, all framing lumber shall be Southern Pine, Grade #2 or better and shall be pressure treated ACQ or CA-B in accordance with American Wood-Preservers' Association Standards. All lumber in contact with the ground shall be rated as "ground contact." Please note that not all treated lumber is rated for ground contact.

#### HARDWARE AND FASTENERS

All hardware and fasteners (joist hangers, post anchors, mechanical fasteners, nails, screws, bolts, etc.) shall be galvanized with 1.85 oz/sf of zinc (G-185 Coating) or shall be stainless steel. Look for products such as "zmax" from simpson-strong-tie or "triple zinc" from USP.

#### **DECKING REQUIREMENTS**

All decking material shall be 2x6 or 5/4 (five-quarter) board. Attach decking to each joist with a minimum of (2) ring shank 8D nails or 2-1/2" wood screws. Decking may be applied diagonally at a 45 degree angle perpendicular to the joists. Decking composed of foreign lumber, composite, or manufactured materials may be substituted only when the product has an approved evaluation report from an accredited testing laboratory. Check with your local building department for approved materials or refer to the list of approved decking products.

Approved composite decking materials list available at: http://www.decks.com/article330.aspx

decks.com	Sheet: 1 of 10 Date: 9-10-2008	Attention: Verify all building practices with local building departments. Decks.com LLC encourages the use of this detail for educational purposes. Decks. com LLC grants permission to reproduce this document, however, editing the docu-
	Copyright: Decks.com LLC	ment is strictly prohibited.

# **Frost Footing Detail**

												Ta	ble	2 1:	Fro	ost I	Foo	otin	g Si	ze	S												-		
										<i>k</i> '			7'		POS	T SP	ACIN	٩G	9'			10'			11'			12'			13'			14'	
			_	4		7	0	E	7	6	5	8	7	6	9	7	6	9	7	6	10	8	7	10	8	7	10	9	7	11	9	8	11	9	8
	6'	Corner Footing	6	5	4	10	0	0	10	0	7	11	à	8	12	10	9	13	10	9	14	11	10	14	12	10	15	12	10	15	13	11	16	13	11
	×	Intermediate Footing	9	8	/	10	0	1	0	7	6	0	7	6	9	8	7	10	8	7	10	8	7	11	9	8	11	9	8	12	10	9	12	10	9
	7'	Corner Footing	7	5	5	10	0	5	0	0	0	12	10	9	13	11	9	14	11	10	15	12	10	15	13	11	16	13	11	17	14	12	17	14	12
	·	Intermediate Footing	9	8	/	10	8	6	0	7	6	0	8	7	10	8	7	10	8	7	11	9	8	11	9	8	12	10	9	13	10	9	13	11	9
	<b>A</b> '	Corner Footing	1	6	b	8	0	0	9	10	0	12	11	à	14	11	10	15	12	10	16	13	11	16	13	12	17	14	12	18	15	13	18	15	13
	•	Intermediate Footing	10	8	/	11	9	8	12	7	9	10	9	7	10	9	7	11	9	8	12	10	8	12	10	9	13	10	9	13	11	9	14	11	10
-	0'	Corner Footing	7	6	5	8	1	0	9	10	0	14	11	10	15	12	10	16	13	11	17	14	12	17	14	12	18	15	13	18	15	13	20	16	14
Ē		Intermediate Footing	10	9	1	12	10	8	13	0	3	10	0	7	11	9	8	12	10	8	12	10	9	13	11	9	14	11	10	14	12	10	15	12	10
<u> </u>	10'	Corner Footing	8	6	6	9	1	0	10	0	10	10	12	10	16	13	11	17	14	12	17	14	12	18	15	13	19	16	14	20	16	14	21	17	15
鱼		Intermediate Footing	11	9	8	12	10	9	14	0	10	10	0	9	12	9	8	12	10	9	13	11	9	14	11	10	14	12	10	15	12	10	15	13	11
Ξ.	11'	Corner Footing	8	7	6	9	/	6	10	8	10	15	12	10	16	13	11	17	14	12	17	14	12	18	15	13	19	16	14	20	16	14	21	17	15
S		Intermediate Footing	12	9	8	13	11	9	14	12	10	15	12	0	10	10	0	13	10	9	14	11	10	14	12	10	15	12	10	15	13	11	16	13	11
0	10'	Corner Footing	9	7	6	10	8	1	10	9	10	10	12	11	17	14	12	18	15	13	19	16	14	20	16	14	21	17	15	22	18	15	23	18	16
	12	Intermediate Footing	12	10	9	14	. 11	10	15	12	10	10	10	0	12	10	0	13	11	9	14	12	10	15	12	10	15	13	11	16	13	11	17	14	12
	12	Corner Footing	9	7	6	10	8	7	11	9	8	12	14	12	10	15	13	19	15	13	20	16	14	21	17	15	22	18	15	23	19	16	24	19	17
	13	Intermediate Footing	13	10	9	14	12	10	15	13	11	1/	14	12	10	11	0	14	11	10	15	12	10	15	13	11	16	13	11	17	14	12	17	14	12
	4.41	Corner Footing	9	8	7	10	8	7	11	9	8	12	10	9	10	16	12	20	16	14	21	17	15	22	18	15	23	18	16	24	19	17	24	20	17
	14	Intermediate Footing	13	11	9	15	12	10	16	13	11	1/	14	12	10	10	10	14	12	10	15	12	11	16	13	11	17	14	12	17	14	12	18	15	13
		Corner Footing	10	8	7	11	9	8	12	10	8	13	10	9	14	16	14	20	17	14	21	17	15	22	18	16	23	19	17	24	20	17	25	21	18
	15	Intermediate Footing	14	11	10	15	12	11	17	14	12	18	15	13	19	11	10	15	12	10	16	13	11	16	13	12	17	14	12	18	15	13	18	15	13
	440	Corner Footing	10	8	7	11	9	8	12	10	9	13	11	9	14	10	10	21	17	15	22	18	16	22	19	16	24	20	17	25	21	18	26	21	18
	10	Intermediate Footing	14	11	10	16	13	11	17	14	12	18	15	13	20	10	14	21	17	10	1 24	10	10												

Requirements for 3-Season Porches or Screen Porches:

- A. Increase corner footing size by 90%
- B. Increase center footing size by 55%
- C. Locate all footings at extremities of deck. (No Cantilevers)

#### FOOTINGS

ings shall be installed below frost line. Check with your local building department for footing depth requirements. All footings shall bear on solid ground.

#### CONCRETE

three soil types:

All Footing sizes above

are base diameters (in

inches) and are listed for

Use a minimum 2,500 PSI concrete mix for frost footing foundations.

(Table 1 Key)

Intermediate Footing

**Comer Footing** 

Concrete anchors and post base connectors shall be galvanized with 1.85 oz/sf of zinc (G-185) coating) or stainless steel.

Clay

6

9

Sand

5

8

Gravel

4

7



#### Copyright: Decks.com LLC

com LLC grants permission to reproduce this document, however, editing the document is strictly prohibited

# HARDWARE

See Table 1 for footing size. Footings must be 8" minimum thickness. Frost foot-

#### **EXCAVATION**

Call before you dig. Have all utilities marked. US Phone numbers available at: http://www.decks.com/article38.aspx

# **Typical Deck Ledger Board Details**

#### GENERAL

Attach the ledger board, which shall be equal to or greater than the joist size, to the existing exterior wall in accordance with the Ledger Board to House Band Detail. When attachments are made to the existing house rim board, the rim board shall be capable of supporting the new deck. If this cannot be verified or the conditions at the existing house differ from the details herein, then a free-standing deck is required. See sheet 5.

#### SIDING AND FLASHING

House siding, or the exterior finish system, must be removed prior to the installation of the ledger board. Flashing is required at any ledger board connection to a wall of wood framed construction and shall be composed of copper (attached with copper nails), stainless steel, UV resistant plastic, or galvanized steel coated with G-185 coating.

Ledger Board To	House Band Detail	1	
House	Flashing	Deckin	
House Joist	Concealed Hanger	2100	Common
S Plate	Back Flash	Joist	

#### MANUFACTURED WOOD JOISTS

Many new homes constructed with manufactured wood "I" joists include a 1-1/4" manufactured solid rim board that can support the attachment of a deck. " However, older homes may be constructed with rim boards that are too thin (less than 1") to support a deck. In such cases a free-standing deck is required or additional interior blocking is needed. See sheet 5.

#### PROHIBITED LEDGER ATTACHMENTS

Attachments to the ends of pre-manufactured open web joists, to brick veneers, hollow concrete block walls and house overhangs or bay windows require additional engineering design..



#### CONCRETE FOUNDATION WALL ATTACHMENT

- Install using 1/2" diameter sleeve anchors with washers.
- Install according to manufacturers' instructions.
- 1/2 " sleeve anchors must be embedded 2-1/2" minimum.
- Top of ledger board must be caulked to resist corrosion and decay.



Sheet: 3 of 10 Date: 9-10-2008

Late: 9-10-2008

Copyright: Decks.com LLC

Attention: Verify all building practices with local building departments

Decks.com LLC encourages the use of this detail for educational purposes. Decks. com LLC grants permission to reproduce this document, however, editing the document is strictly prohibited.

# **Typical Deck Ledger Board Details 2**

### Ledger Board Fastener Spacing



#### LEDGER BOARD FASTENERS

The spacing between ledger board fasteners is dependent on the span length of the joists. Use the following table to determine fastener spacing and install to the configuration in Table 2. All fasteners shall be installed with washers and must be thoroughly tightened.

#### LAG BOLTS

Lag bolts shall be a minimum 1/2" and installed with washers. Lag bolts must be hot-dipped galvanized or stainless steel. Lag bolts must penetrate beyond rim board a minimum of 1/2".

#### LAG BOLT INSTALLATION REQUIREMENTS

#### Each lag bolt shall have pilot holes drilled as follows:

- 1) Drill a 1/2" pilot hole in the ledger board.
- Drill a 5/16" diameter hole into the solid connection material of the existing house.

Do not drill a 1/2" diameter hole into the solid connection material. The threaded portion of the lag screw shall be inserted into the pilot hole by turning. Do not drive with a hammer. Each lag screw shall be thoroughly tightened.

#### Table 2: Ledgerboard Fastener Schedule

Joist	Fastene	er Spacing, On C	enter
Span	1/2" Lag Screws	WHHB*	Thrubolts
0' - 6'	30"	16″	36"
6' - 8'	23"	12"	36"
8' - 10'	18"	10"	34"
10' - 12'	15"	8"	29″
12' - 14'	13"	7″	24"
14' - 16'	11."	6"	21"
16' - 18'	10"	5″	19"

\*Washer Headed Hardened Bolts





Sheet: 4 of 10

Date: 9-10-2008

Copyright: Decks.com LLC

Attention: Verify all building practices with local building departments.

Decks.com LLC encourages the use of this detail for educational purposes. Decks. com LLC grants permission to reproduce this document, however, editing the document is strictly prohibited.

# Lateral Support Of Free Standing Deck

#### Lateral Support of Free Standing Deck



#### FREE STANDING DECKS

Decks which are free-standing do not utilize the exterior wall of the existing house to support vertical loads; instead an additional beam with posts is provided at or within 2' of the existing house. The associated deck post footings must be installed on virgin or compacted soil to prevent sinking. Free standing decks greater than 2 feet above grade shall resist lateral loading and horizontal movement by providing diagonal bracing or by attaching the deck to the exterior wall of the house.

#### **DIAGONAL BRACING**

Provide diagonal bracing both parallel and perpendicular to the beam at each post as shown in lateral support of free standing deck detail. When parallel to the beam, the bracing shall be bolted to the post at one end and beam at the other. When perpendicular to the beam, the bracing shall be bolted to the post at one end and the joist at the other. When a joist does not align with the bracing location, provide blocking between the next adjacent joists.

#### SWAY BRACING

All decks using horizontal decking should have a diagonal sway brace to prevent racking. Install metal "T Bracing" diagonally across the top of joists or fasten a diagonal deck board below the deck frame decks using diagonal decking do not require sway bracing

#### **Sway Bracing**





Sheet: 5 of 10

Date: 9-10-2008

Copyright: Decks.com LLC

Attention. Verify all building practices with local building departments

Decks.com LLC encourages the use of this detail for educational purposes. Decks. com LLC grants permission to reproduce this document, however, editing the document is strictly prohibited.

# PROTECT YOUR INVESTMENT TWO WAYS



#### CREATE YOUR OUTDOOR LIVING ROOM

Trex RainEscape is a unique under-deck drainage system – a network of troughs and gutters – that keeps rain, spills and snow melt from dripping through elevated deck boards. RainEscape creates a dry patio area on the ground level, enabling the homeowner to safely add lighting fixtures, ceiling fans, entertainment systems and more.





#### ENSURE THE LIFE OF YOUR DECK

Trex Protect Joist and Beam Tape is a selfadhesive butyl tape designed to protect the top of your joist or beam from moisture that can lead to joist rot and loosening of the deck screws and fasteners. Trex Protect acts as a barrier between wood and galvanized metal and also helps hold screws longer and stronger.



#### trex.com

Trex<sup>®</sup> RainEscape<sup>®</sup> and Trex<sup>®</sup> Protect<sup>™</sup> are manufactured and/or distributed by Dri-Deck Enterprises, LLC. Trex<sup>®</sup> is a trademark of, and is used by Dri-Deck Enterprises, LLC. under a license with, Trex Company, Inc.

# **Deck Beam and Joist Details**

#### **BEAM SIZING**

Based on No. 2 or better Ponderosa and Southern Pine. (treated for weather and/or ground contact)

4			_			lac	DIE 3: BEA	M SIZE					
							POST SPAC	ING					
			4	5	6	7	8	9	10	11	19	12	10
	6'	Southern Pine	1-2×6	1-2x6	1-2x6	2-2x6	2-2x6	2-2x6	2-2×8	2.2v8	2.2×10	2 2:10	14
		Ponderosa Pine	1-2x6	1-2×6	2-2x8	2-2x8	2-2x8	2-2×8	2-2×10	2.2×10	2-2×10	2-2x10	2-2×10
	7'	Southern Pine	1-2x6	1-2x6	1-2x6	2-2x6	2-2×6	2-2×8	2.2x8	2.2×10	2-2312	2-2x12	3-2x10
		Ponderosa Pine	1-2×6	1-2x6	1-2x8	2-2x8	2-2x8	2-2×10	2-2×10	2-2×10	2-2×10	2-2×10	2-2x12
	8'	Southern Pine	1-2x6	1-2x6	2-2x6	2-2x6	2-2x8	2-28	2.2.0	2-2210	2-2x12	3-2x10	3-2×10
		Ponderosa Pine	1-2x6	2-2x6	2-2x8	2-2x8	2-2x8	2-2×10	2.2.40	2-2x10	2-2x10	2-2x12	2-2×12
-	0'	Southern Pine	1-2×6	1-2x6	2-2x6	2-2×6	2-2x8	2.2.0	2-2×10	2-2X10	3-2x10	3-2x10	3-2x12
Ē		Ponderosa Pine	1-2x6	2-2×6	2-2x8	2-2×8	2-2×10	2.2.10	2-2×10	2-2x10	2-2×12	2-2x12	3-2x10
ÿ	10'	Southern Pine	1-2x6	1-2x6	2-2x6	2-2×6	2-2-2	2 2.0	2-2X10	3-2x10	3-2×10	3-2x12	3-2x12
ίų.	10	Ponderosa Pine	1-2x6	1-2×6	2-2×8	2-2×8	2.2×10	2-220	2-2×10	2-2x12	2-2×12	3-2×10	3-2×10
E.	14'	Southern Pine	1-2×6	2-2×6	2-2×6	2.2×8	2.2×10	2-2x10	Z-2x12	3-2x10	3-2x12	3-2x12	Eng Bm
S		Ponderosa Pine	2-2x6	2-2×6	2-2×8	2.2.8	2-2.0	2-2x10	2-2×10	2-2×12	2-2×12	3-2×10	3-2×12
0	10	Southern Pine	1-2x6	2-2x6	2-2×6	2.2.0	2-2210	2-2x12	2-2x12	3-2×10	3-2×12	3-2x12	Eng Bm
-	12	Ponderosa Pine	2-2x6	2-2x6	2.2.8	2.2×10	2-288	2-2x10	2-2×10	2-2x12	3-2x10	3-2x10	3-2x12
	4.91	Southern Pine	1-2×6	2-2×6	2.2×6	2-2310	2-2X10	2-2x12	2-2x12	3-2x12	3-2×12	Eng Bm	Eng Bm
	13	Ponderosa Pine	2-2×6	2-2×6	2.2.0	2-2.0	2-2x8	2-2×10	2-2×10	2-2x12	3-2×10	3-2x12	3-2x12
		Southern Pine	1-2×6	2.2×6	2.2.40	2-2X10	2-2x12	2-2x12	2-2×12	3-2x12	3-2x12	Eng Bm	Eng Bm
	14	Ponderosa Pine	2-2×6	2.2.0	2-2.0	2-2x8	2-2x10	2-2x10	2-2x12	3-2x10	3-2x12	3-2x12	3-2x12
		Southern Pine	2.2×6	2-2.00	2-2x8	2-2x10	2-2x12	3-2x10	3-2x12	3-2x12	Eng Bm	Eng Bm	Eng Bm
	15	Ponderosa Pine	2.2×6	2-2x0	2-2x8	2-2×8	2-2x10	2-2×12	2-2×12	3-2x10	3-2×12	3-2x12	Eng Bm
		Southern Pine	2.2×0	2-2x8	2-2x8	2-2×10	3-2x10	3-2x10	3-2×12	3-2x12	Eng Bm	Eng Bm	Eng Bm
	16'	Ponderoca Pino	2-2.0	2-2x6	2-2x8	2-2x8	2-2×10	2-2x12	2-2x12	3-2x10	3-2×12	3-2×12	Eng Bm
-		r underusa Pine	Z-2x6	2-2x8	2-2x10	2-2x10	3-2x10	3-2×10	3-2x12	3-2x12	Eng Bm	Eng Bm	Eng Bo

Joist sections cantilevered over beams must be calculated as (2X Length) for beam sizing. See cantilevered beam detail: 2A + B = Total Joist Length





Joist To Beam Connection Detail

#### **OPTION A**

(3) 8D Toe Nailed, (2 on one side, 1 on the other.)

#### **OPTION B**

Mechanical fastener or hurricane clip.

#### OPTION C

Joist hanger top of beam and joist must be at same elevation.

lab	01	$\cap$	T 2		75
iuo			1.2.1	3	

	PO	NDEROSA P	INE	S	DUTHERN PI	NE	W	ESTERN CED	AR
	12" O.C.	16" O.C.	24" O.C.	12" O.C.	16" O.C.	24" O.C.	12" O.C.	16" O.C.	24" O.C.
2x6	9'-2"	8'-4"	7'	10'-9"	9'-9"	8'-6"	9'-2"	8'-4"	7'-3"
2x8	12'-1 "	10'-10"	8'-10"	14'-2"	12'-10"	11'	12'-1"	11'	9'-2"
2x10	15'-4"	13'-3"	10'-10"	18'	16'-1"	13'-5"	15'-5"	13'-9"	11'-3"
2x12	17'-9"	15'-5″	12'-7"	21'-9"	19'	15'-4"	18'-5"	16'	13'

Based on no. 2 or better wood grades. (design load = 40 lbs live load + 10 lbs dead load, deflection I/360)



Sheet: 6 of 10	Attention. Verify all building practices with local building departments.
Date: 9-10-2008	Decks.com LLC encourages the use of this detail for educational purposes. Decks.
Copyright: Decks.com LLC	com LLC grants permission to reproduce this document, however, editing the document is strictly prohibited.

# **Post and Beam Detail**

#### **Beam Nailing And Post Notch Detail**



#### POST REQUIREMENTS

All deck support posts shall be 6x6, and the maximum height shall be 14'-0".

#### BEARING

Beams shall have a minimum 1-1/2" solid bearing on top of support posts.

Recommended: nail beams with (5) 2 1/2 framing nails spaced every 16" on center from front and back. Required: 16D (3-1/2") at 16" on center along each edge.

- A Interior mounted rail post lag bolted to deck rim
- B Post beam connector
- Corner support post to provide full bearing support to both sides of 45 degree beam

#### 45 Degree "Clipped Corner" Framing Post And Beam Connection



#### Multilevel Deck: Compound Post Connection Detail



- A Post notch.
- B Maximum 1" lateral beam overhand of support post.
- C Deck beam set on notched 6x6 post and through bolted with (2) 1/2" bolts with washers.
- D 6x6 support post.
- E Concealed joist hanger.
- F 2x6 post cleat bolted to side of 6x6 post to extend beam bearing.



Sheet: 7 of 10

Date: 9-10-2008

Copyright: Decks.com LLC

Attention: Verify all building practices with local building departments.

Decks.com LLC encourages the use of this detail for educational purposes. Decks. com LLC grants permission to reproduce this document, however, editing the document is strictly prohibited.

### **Typical Stair Detail**

#### **Typical Stair Detail**



#### STAIR TOLERANCES

Maximum 4" opening at risers greater than 30" above grade. Minimum stair width is 36". Maximum rise is 7-3/4". Minimum recommended rise is 4". Minimum tread depth is 10". Largest tread width or riser height shall not exceed the smallest by more than 3/8". Maximum 4" opening at risers greater than 30" above grade.

#### STAIR STRINGERS

All stringers shall be 2x12 Southern Pine. Stair stringer spacing is 16" O.C. typical for 5/4x6 wood treads. Verify stair stringer spacing for composite stair treads.

#### STAIRWAY ILLUMINATION

All exterior stairways shall be illuminated at the top landing to the stairway. Illumination shall be controlled from inside the dwelling or automatically activated.

#### HEADROOM

Stairs shall be provided with a minimum of 6'-8" headroom clearance. The clearance shall be measured from the nosing of the treads to the ceiling or soffit directly above that line.

#### STAIR GUARD RAIL REQUIREMENTS

Guards are required on the side(s) of stairs with a total rise of more than 30"



Sheet: 8 of Date: 9-10-2

Copyright: [

#### LEGEND

- A Grippable Handrail
- B 4-3/8" Max. Sphere
- C 6" Max. Sphere
- D Stair landing: 3'x3' minimum landing at bottom of stairs. Flat ground may qualify.
- Stair tread: Minimum tread depth is 10". E
- F Stair riser: Maximum rise: 7-3/4", recommended minimum rise: 4".
- 36" minimum stair width G
- H 34" 38" guard rail height above stair nosing



above the floor or grade below. Guards on stairs must be not less than 34" high measured from the nosing of the treads. All required guard rails must have intermediate rails or decorative pattern such that a 4 3/8" diameter sphere will not pass through except that the triangular space formed by the bottom of the guard rail. The stair tread, and stair riser may be such that a 6" diameter sphere will not pass through.

Guard rails must be designed to support a 200 lb. load applied in any direction at any point along the top of the guard rail.

#### **GRIPPABLE HANDRAIL**

The top of the handrail shall not be placed less than 34" or more than 38" above the nosing of the treads. The handgrip shall have a smooth surface with no sharp corners. Handrails shall be continuous the full length of the stairs and returned to posts or wall at the ends. The handgrip portion of the handrail shall not be less than 1-1/4" or more than 2-5/8" and shall provide a grippable surface. There are many acceptable styles of handrails that meet the minimum requirements. Consult your local building department.

Attention: Verify all building practices with local building departments.
Decks.com LLC encourages the use of this detail for educational purposes. Decks.
<ul> <li>com LLC grants permission to reproduce this document, however, editing the document is strictly prohibited.</li> </ul>

# **Typical Stair Attachment Detail**



- A Deck rim joist.
- B Attach stair guard rail 4x4 posts to stair stringers with (2) 1/2" lag bolts with washers.
- C 2x4 Bottom plate extends deck rim to bottom of stair stringer connection.
- Mechanical connection strap tie forms continuous positive connection between rim, plate, stair stringer.
- E 2x12 stair stringer.

- A Deck rim joist.
- B Outside stair stringers attached to guard rail 4x4 posts with (2) 1/2" lag bolts with washers.
- C Stair stringer fastened to deck frame with joist hanger or equivalent positive connection.
- D 2x4 bottom plate extends deck rim to bottom of stair stringer connection.
- E 2x12 stair stringer.

**Cascading Stair Detail** 

# Stair Stringer Attachment Detail: Front View

B

C

E

Om

D

- A 2x4 bottom plate extends deck rim to bottom of stair stringer connection.
- B Stair stringer fastened to deck rim with joist hanger or equivalent positive connection.
- C 2x12 stringer spaced 16" O.C.
- D Recommended 2 2x8 base header must be .60 RET treated rated for ground contact
- E Install blocking to support decking seams.
- F Footing recommended stair may rest on landscaping.

Stairs may rest on landscaping.

Not all composite decking materials are approved for use on stairs.



MIL

#### Sheet: 9 of 10

Date: 9-10-2008

Copyright: Decks.com LLC

Attention: Verify all building practices with local building departments

Decks.com LLC encourages the use of this detail for educational purposes. Decks. com LLC grants permission to reproduce this document, however, editing the document is strictly prohibited.

# **Typical Guard Rail Detail**

# Guard Rail Detail

- A 4x4 Rail post typical do not notch.
- B 6'0" maximum rail post spacing.
- C 2x6 or 5/4 board rail cap.
- D 2x2 rail picket, typical.
- E 2x4 top and bottom. Attach to guard post with 2
   16D nails on inside face.
- F Openings shall not allow the passage of a 4" diameter sphere.
- G Attach pickets at top and bottom with 2 1/2" wood screw of 2 - 10D or 12D spiral shank nails.
- H 2 1/2" diameter thru-bolts and washers.
- 1 36" minimum rail height.

#### **GUARD RAIL REQUIREMENTS**

All decks greater than 30" above grade are required to have a guard rail. If your are providing a guard rail when one is not required, it should still meet these requirements. All guard rails shall be constructed in strict conformance with the following details. Any pre-fabricated wood, composite, or metal manufactured rail system must be approved by your local building department.

#### ATTENTION

Do not notch guard rail posts at deck connection. Do not bolt through the top or bottom 1-1/2" of deck joists or beams.



- A Install 4x4 guard rail post flush to outside of rim joist with (2) 1/2" lag bolts with washers.
- B Install 2 guard rail posts for 90 degree corners when attaching guard rails to outside of deck rim.



- A Install bracing for added rim strength to stiffen guard rails
- B Install 1 corner guard rail post when attaching guard rails to inside of deck rim before decking is installed.



Sheet: 10 of 10

Date: 9-10-2008

Copyright: Decks.com LLC

Attention, Verify all building practices with local building departments

Decks.com LLC encourages the use of this detail for educational purposes. Decks. com LLC grants permission to reproduce this document, however, editing the document is strictly prohibited.