





Power System Engineering About the Presenter Mr. Asp earned a BS degree in Electrical Engineering from North Dakota State University and an MBA from the University of St. Thomas - St. Paul, MN. He has more than 40 years of experience in communication planning and business development for electric cooperative and public power systems and is recognized as a nationwide expert in evaluating and offering recommendations regarding electric utility broadband communications systems. Tom has been actively involved with AMI, market research, network Tom Asp feasibility analysis, broadband system design, and the preparation of financial Senior Utility Automation statements and quantitative business plan analysis for electric cooperative, and Communications Consultant municipal, and public power clients for more 20 years. aspt@powersystem.org He also has extensive experience presenting to utility leadership, conducting Direct: 608-268-3509 needs assessment interviews, and facilitating stakeholder sessions. 2













Power System Engineering
What is AMI
• Advanced Metering Infrastructure (AMI): integrated system of electric and water meters, communications networks, and data management systems that enables two-way communication between utilities and consumers.
• Provides functionality not previously possible or had to be performed manually:
 automatically and remotely measure electricity use
 – connect and disconnect service
- detect tampering
 identify and isolate outages
– monitor voltage
AMI is a growing component of the energy system because it allows an understanding of how energy is generated and transmitted to customers. Utilities can improve parts of the energy system based on their findings using AMI data that they have collected and analyzed.
© 2023 Power System Engineering, Inc. 7







				Power System Engineering
How Many	AMI Meters are	Installed in the	e US, and Who	Has Them?
 about 111 millie equal to about 6 meters installati Includes meters record electricit of hourly interv 	ectric utilities had on AMI installation 99% of total electric ons. that measure and y usage at a minimu als and provide data omer at least once a	s, um a to	ter adoption rates by state, 2016	Percent of residential customers with mart meters 21% to 20% 21% to 40% 41% to 60% 61% to 80% 81% to 100%
I	Number and percentag	ge share of AMI install	ations by sector, 202	1 ¹
Residential	Residential Commercial		Transportation	Total
97,708,824 (69%)	708,824 (69%) 12,930,423 (66%) 53		1,786 (52%)	111,176,758 (69%)
© 2023 Power System Engineering, Inc.			•	9













	Power Syste
	Health Concerns from Exposure to RF Emissions of AMI Meters
	Radio Frequency (RF) radiation is low-energy radiation; not enough energy to remove electrons from an atom or molecule (ionize), so called non-ionizing radiation.
	 Non-ionizing radiation has enough energy to move atoms in a molecule around or cause them to vibrate, which can lead to heat, but it can't damage DNA directly².
	 ~25,000 articles published over past 30 years on biological effects and medical applications of non-ionizin radiation. Despite feeling of some that more research is needed, scientific knowledge in this area is now more extensive than for most chemicals³.
	 Scientists are investigating effects below threshold level for body heating as a result of long-term exposur To date, no adverse health effects from low level, long-term exposure to radiofrequency or power frequer fields have been confirmed (scientists are actively continuing to research this area).
	AMI meters do not continuously transmit. Utilities typically read meters once every 15 minutes and time to transmit data is less than 1 second or ~ $.011\%^4$ of the day. (Even if transmits once every 15 seconds, would on be 6.7% of the day.)
	The system Niles would install would transmit only once every 4 hours.
	Not new in consumer market – debate continues with Wi-Fi and other wireless deploymen
6 2	1023 Power System Engineering, Inc.


























Power System Engineering, Inc.








Opt-Out Program

- Some consumers will object to having AMI meter; consider an opt-out program
 - Typically, one time charge to cover cost to remove and replace meter
 - Ongoing charge per reading to cover added cost of manual meter read
- Customers opting-out may see diminished service offerings
 - Outage and restoration verification may be delayed – causing repeat visits
 - Longer lead time to investigate service issues (low or high voltage, high bill, etc.)

Examples of Opt-Out Programs Cowlitz PUD, Longview, WA AMI meter replacement with analog - \$135; Monthly fee - \$25 Electrical District Number 3, Maricopa, AZ Enrollment fee - \$75; Monthly fee - \$30 Sacramento Municipal Utility District (SMUD) Set up fee - \$127; Monthly fee - \$14 Duke Energy Progress, NC Enrollment Fee \$170; Monthly fee - \$14.75 Rochester, Minnesota Initial setup fee \$200; Monthly fee for Electric \$80, Water \$55





	Power System Engineering								
Example Use Cases									
Historical Outage & Restoration	Load Management								
 Data refresh year-over-year 	 Measurement and Verification 								
 Heat maps for quick identification 	 Rebates vs. participation 								
System Line Loss Analysis	• Estimates vs. As-Builts								
- System vs. Substation vs. Feeder	 Project cost tracking 								
Rate Impacts	– Are estimates within range?								
– Are members in the right or best rate class?	• Voltage								
 Coincident Peak Billing 	- High and low voltage detection								
High Bill	- End of line vs. mid-line								
 Preemptive trending and potential high bills 									
© 2023 Power System Engineering, Inc.	26								





Power System Engineering 70 **Asset Management** We are getting better at using data ٠ DNV-GL sources to prevent outages Risk by KPI SAIDI -Aggregated Risk - Predictive failures/risk assessments – Number of operations CHES 6761 0 612 - Temperature e - Demand - Timed Inspections - Better maintenance records and supply chain management Ordering the right equipment, we need ____ when we need it i di 28 28



















										D.			4											
										R	aw	Da	ta											
AutoSave 💽 🖁 🐇	>• @≈8			Su	bmetered A-C xlsx	Excel			2	Search											Корсту	k Kile 🙆		a
	Draw R	Page Layout	Formu	las Data	Review View	/ Help																	🖻 Share	
	Calibri	- 11 -	A" A"	三三五	参~ 袋 Wrap	ext	Genera	0	-			Normal	Bad		Good	N	eutral	<u>_</u>	🎬 🎫 🖻		utoSum ~	48 C) 4	63
Paste Le Copy *	BIU~	H- 0	. A .				5 -	% .	8 .91 0	Conditional	Format as	Calculatio	n Che	ck Cell	Explanat	ory In	put	- 1	nsert Delete Forr	nat Ori	I.~	Sort & Find	B: Ideas	Sensitivity
- 💞 Format Painter		-	_)					E F	ormatting ~	Table ~				-					Ø a		Filter ~ Select		
Clipboard Fa		Font	ri,		Alignment		rai t	Number	191					Styles					Cells		Editi	ng	Ideas	Sensitivity
K23 * I ×	√ Sr.	1.28																						
A A A A A A A A A A A A A A A A A A A	B		D	E F	G 7748 15638572 10		1	J	K	L	M	N	0	P					U V 83690 16883707	W 16920795	X 16990914	Y 12024194	Z	AA AI 7116073 1711
2 Description					//48 15638572 10 h Fo (1 kWh Fo (1																			
3 5/1/2020 0:00 5	/1/2020 0:30	0	0	0.32	0 0	0	0	0.96	0.16	0	0	0	0	0	0	0	0	0	0 0			0	0	0
	/1/2020 1:00	0	0	0.48	0 0	0	0	0	0	0	0	0	0	0	0	0	0	0.32	0 0			0	0	0
	/1/2020 1:30 /1/2020 2:00	0	0	0	0 0	0	0	1.024	0.16	0	0	0,48	0	0	0	0	0	0.16	0 0		0	0	0	0
	/1/2020 2:30	0	0	0.16	0 0	0	0	0.10	0.16	0	0	0.48	0	1.12	0	0.16	0	0.10	0 0			0	0	0
	/1/2020 2:50	0	0	0.48	0 0	0	0	0.952	0.32	0	0	1.04	0	0	0	0.48	0	0.52	0 0			0	0	0
	/1/2020 3:30	0	0	0	0 0	0	0	0.032	0	0	0	1.92	0	1.12	0	0	0	0.32	0 0		0.08		0	0
	/1/2020 4:00	0	0	0	0 0	0	0	0	0.16	0	0	2.32	0	0	0	0	0	0	0 0	0 0	0	0	0	0
	/1/2020 4:30	0	0	0	0 0	0	0	0	0.16	0	0	2.4	0	1.12	0	0	0	0.32	0 0	0 0	0	0	0	0
	/1/2020 5:00	0	0	0	0 0	0	0	0	0	0	0	2.32	0	0.96	0	0	0	0.32	0 0		0	0	0	0
	/1/2020 5.30	0	0	0	0 0.8	0	0	0	0.10	0	0	2.4	0	1.70	0	0	0	0.10	0 0		0	0	0	0
	/1/2020 6:00 /1/2020 6:30	0	0	0	0 0.95	0	0	0	0.16	0	0	2.32	0	1.44	0	0.48	0	0.32	0 0		0100		1.44	0
	/1/2020 7:00	1.92	0	0.16	0 0.52	0	0	0	0.16	0	0	2.32	0	3,84	0	0.32	0	0.32	0 0		0.24	0	1.28	0
	/1/2020 7:30	0	0	0.64	0 0	0	0	0	0.16	0	0	2.32	0	2.88	0	0	0	0.32	0 0		0	0	1.44	0
	/1/2020 8:00	0	0	0	0 0	0	0	0	0	0	0	2.32	0	3.36	0	0	0	0.16	0 0	0 0	0	0	1.44	0
	/1/2020 8:30	0	0	0	0 0	0	0	0	0.16	0	0	2.24	0	4.96	0	0	0	0.16	0 0		0	0	1.28	0
	/1/2020 9:00	0	0	0	0 0	0	0	0	0.16	0	0	1.44	0	4.96	0	0.32	0	0.48	0 0				1.44	0
	/1/2020 9:30	0	0	0	0 0	0	0	1.408	1.12	0	0	0	0	5.12	0	0.48	0	0.32	0 0		0.24	0	1.44	0
	1/2020 10:00	0	0	0.8	0 0	0	0	0.16	1.28	0	0	0	0	5.12	0	0	0	0.32	0 0			0	1.28	0
	1/2020 10:50	0	0	0.0	0 0	0	0	0.768	1.28	0	0	0	0	5.28	0	0	0	0.52	0 0			0	1.44	0
	1/2020 11:30	0	0	0.16	0 0.08	0	0	0.224	1.28	0	0	0	0	4.8	0	0	0	0.32	0 0	0 0	0	0	0	0
	1/2020 12:00	0	0	0.64	0 0.96	0	0	0.64	0.8	0	0	0	0	4.8	0	0	0	0.32	0 0			0	0	0
27 5/1/2020 12:00 5/		0	0	0.16	0 0.48	0	0	0.32	0.16	0	0	0	0	2.08	0	0	0	0	0.08 0			0	0	0
	1/2020 13:00	0	0	0.96	0 0	0	0	0	0	0	0	0	0	1.44	0	0	0	0	0.08 0		0	0	0	0
	1/2020 13:30 1/2020 14:00	0	0	0.16	0 0	0	0	0.896	0	0	0	0	0	0	0	0	0	0	0.16 0		0.16	0	0	0
	1/2020 14:00	0	0	1.44	0 0	0	0	0.896	0	0	0	0	0	0	0	0	0	0	0.16 0			0	0	0
	1/2020 15:00	0	0	1.44	0 0	0	0	0.050	1.12	0	0	0	0	0	0	0	0	0	0.16 0		0.10	0	0	0
	1/2020 15:30	0	0	0	0 0	0	0	0	1.28	0	0	0	0	0	0	0	0	0	0.24 0	0 0	0	0	0	0
34 5/1/2020 15:30 5/		0	0	1.44	0 0	0	0	0.832	1.28	0	0	0	0	0	0	0	0	0	0.16 0			0	0	0
35 5/1/2020 16:00 5/		0	0	1.12	0 0	0	0	0	1.28	0	0	0	0	0	0	0	0	0	0.24 0		0	0	0	0
36 5/1/2020 16:30 5/		0	0	1.28	0 0.64	0	0	0.8	1.28	0	0	0	0	0	0	0	0	0	0.24 0	0 0	0	0	0	0
BR10 E	R11 BR17	۲													4									

