

City of St George/Air Gap Verification Form

MOBILE APPLICATIONS



All mobile tanks shall be equipped with an air gap device and brought to the City Water Yard at 620 E. Waterworks Dr. for annual inspection. An inspection sticker will then be issued and placed on the tank in a visible location. **Appointment Necessary: Call 435-627-4802 Monday – Friday, 8 AM – 3 PM.**

This form must be filled out and signed by the owner/owner's agent who is responsible for the fabrication, maintenance and repair of any air gap to be used on tank trucks, trailer mounted fill spouts or any other tank designed to carry water obtained from any potable water source in St George City distribution system.

A copy of the completed Air Gap Verification form will be kept on file at the Water Department office.

MINIMUM SPECIFICATIONS FOR A MOBILE AIRGAP: (Applies to external piping only)

1. Vertical distance from discharge pipe to the flood level of the container must be at least two times the diameter of the discharge pipe. (1" minimum)
2. No hoses to prevent spillage or splashing shall be attached to the discharge pipe at any time.



VEHICLE: Make: _____ License Plate #: _____

COMPANY: _____ PHONE: (____) _____

ADDRESS: _____ STATE: _____ ZIP: _____

The above-described vehicle and air gap specification exists at this time and will be maintained at all times in the future. I understand that not maintaining this air gap specification is in violation of City Ordinance 8-2-4.

Violation of these Regulations can result in your business license being suspended or revoked in addition to other fines and penalties.

OWNER/PRESIDENT: _____ Date _____

Certified Backflow Administrator: _____ Date _____

No solution tank is being used for this Company (hand pump only) _____ (Initial).