

**ORDINANCE NO. 2022-24**

**AN ORDINANCE AMENDING CHAPTER 74, UTILITIES, ARTICLE II, WATER, DIVISION 5, DISTRIBUTION SYSTEM SPECIFICATIONS, SECTION 74-165, SETTING HYDRANT OF THE CODE OF ORDINANCES FOR THE VILLAGE OF CHERRY VALLEY, ILLINOIS**

**WHEREAS**, the Village of Cherry Valley, Illinois (“Village”) has adopted a Code of Ordinances (“Code”) for the Village; and

**WHEREAS**, the Village wishes to amend Chapter 74, Utilities, Article II, Water, Division 5, Distribution System Specifications, Section 74-165, Setting Hydrant, of the Code; and

**WHEREAS**, the Village has determined that adopting such a ordinance is in the best interest of the Village and its citizens.

**NOW, THEREFORE, BE IT ORDAINED** by the President and Board of Trustees of the Village of Cherry Valley, Illinois as follows:

1. Chapter 74, Article II, Division 5, Section 74-165 of the Code of Ordinances is hereby amended to read as follows (additions shown as **bold and underlined** and deletions as ~~strikethroughs~~) (all other sections not amended shall remain as written):

Sec. 74-165. - Setting hydrant.

- (a) Hydrants shall be located as shown on the plans or as otherwise directed. One hydrant shall be set at each street intersection. Intermediate hydrants shall be set so that hydrants are no more than 300 feet apart. The village shall also allow placement of hydrants within ~~600~~ **1000** feet in areas, **which**, in the village's sole opinion, **are** not expected to develop.
- (b) All hydrants shall stand plumb and shall have their nozzles parallel with or at right angles to the curb, with the pumper nozzle facing the curb. No portion of the pumper or hose cap shall be less than 24 inches from the gutter face of the curb. Hydrants shall be set to the finished grade, with all nozzles at least 18 inches above the finished grade, or as specified by the manufacturer.
- (c) Each hydrant shall be connected to the main by a six-inch diameter branch line controlled by an independent six-inch gate valve with a valve box placed within 18 inches of the front of the hydrant. Each hydrant shall be placed upon a two-foot square concrete base set upon undisturbed soil. The hydrant will be backfilled in accordance with the manufacturer's, AWWA's or standard specifications for water and sewer construction in the state.

2. Except as amended in this Ordinance, all other provisions and terms of Village Code of Ordinances shall remain in full force and effect as previously enacted except that those ordinances, or parts thereof, in conflict herewith are hereby repealed to the extent of such conflict.
3. This ordinance shall be in full force and effect after its approval, passage, and publication in pamphlet form as required by law.

PASSED UPON MOTION BY: NANCY BELT

SECONDED BY: SALLY HOLLEMBEAK

BY ROLL CALL VOTE THIS 7<sup>TH</sup> DAY OF JUNE, 2022

AS FOLLOWS:

VOTING "AYE": NANCY BELT, JEFF FUSTIN, SALLY HOLLEMBEAK,  
MIKE NEVILLE, BRANDI PEARSE

VOTING "NAY": NONE


ABSENT, ABSTAIN, OTHER: CARL WEDIG

APPROVED: JUNE 7, 2022

ATTEST:



DAVID SCHROEDER, VILLAGE PRESIDENT



KATHY TRIMBLE, VILLAGE CLERK